VPDES PERMIT PROGRAM FACT SHEET

FILE NO: 580

This document gives pertinent information concerning the VPDES Permit listed below. This permit is being processed as a **MINOR MUNICIPAL** permit.

1.	PERMIT NO.: VA00	167423	EXPIRATION DATE: October 25, 2009
2.	FACILITY NAME AN	ID LOCAL MAILING	FACILITY LOCATION ADDRESS (IF DIFFERENT)
	Tangier WWTP P. O. Box 244 Tangier, VA 234	40	7448 Wastewater Treatment Plant Rd. Tangier, VA 23440
	CONTACT AT FACIL NAME: Mr. Bryan TITLE: Plant Ope PHONE: (757) 787	Horton	CONTACT AT LOCATION ADDRESS NAME: Mr. Chris Pruitt TITLE: Plant Manager Trainee PHONE: (75)-891-2303
3.	NAME: Ms TITLE: To COMPANY NAME: To ADDRESS: P.	TO RECEIVE PERMIT) Renee Tyler wn Manager wn of Tangier O. Box 244 ngier, VA 23440	CONSULTANT CONTACT: NAME: FIRM NAME: ADDRESS:
		57) 891-2438	PHONE: ()
1 .		: DEQ, Water Permits : R. E. Smithson	Date(s): 07/08/09 Date(s): 07/72/09
5.	() Board Modifica	ation () Change o	Revoke & Reissue () Owner Modification f Ownership/Name [Effective Date:]
, <u>.</u>	Attachment 1 Attachment 2 Attachment 3 Attachment 4 Attachment 5 Attachment 6	TABLE I - Discharge TABLE II - Effluent Effluent Limitation	ort/Memorandum
	Attachment 7 Attachment 8 Attachment 9 Attachment 10 Attachment 11 Attachment 12	Special Conditions Receiving Waters In	Rationale fo./Tier Determination/303(d) Listing Info BLE III(b) - Change Sheets t

APPLICATION COMPLETE: 07/06/09 (DSS Letter)

7.	PERMIT CHARACTERIZATION: (Check as many as appropriate)
	(X) Existing Discharge (I) Proposed Discharge (IX) Municipal (IX) Municipal (IX) Municipal (IX) Municipal (IX) WET Limit (IX) SIC Code(s) 4952 (IX) Interim Limits in Permit (IX) Industrial (IX) POTW (IX) PO
8.	RECEIVING WATERS CLASSIFICATION: River basin information.
	Outfall No(s): 001 Receiving Stream: Chesapeake Bay River Mile: 61.0 Basin: Chesapeake Bay/Atlantic Ocean and Small Coastal Subbasin: N/A Section: 2 Class: II Special Standard(s): a, NEW 20 Tidal: YES
9.	FACILITY DESCRIPTION: Describe the type facility from which the discharges originate.
	Existing municipal discharge resulting from the discharge of treated domestic sewage.
10.	LICENSED OPERATOR REQUIREMENTS: () No (X) Yes Class: III
11. 12.	RELIABILITY CLASS: I SITE INSPECTION DATE: May 15, 2009 REPORT DATE: May 22, 2009
	Performed By: S. J. Thomas
	SEE ATTACHMENT 1
13.	DISCHARGE(S) LOCATION DESCRIPTION : Provide USGS Topo which indicates the discharge location, significant (large) discharger(s) to the receiving stream, water intakes, and other items of interest.
	Name of Topo: Tangier Island, VA Quadrant No.: 143C SEE ATTACHMENT 2
L4.	ATTACH A SCHEMATIC OF THE WASTEWATER TREATMENT SYSTEM(S) [IND. & MUN.]. FOR INDUSTRIAL FACILITIES, PROVIDE A GENERAL DESCRIPTION OF THE PRODUCTION CYCLE(S) AND ACTIVITIES. FOR MUNICIPAL FACILITIES, PROVIDE A GENERAL DESCRIPTION OF THE TREATMENT PROVIDED.
	SEE ATTACHMENT 3

15. **DISCHARGE DESCRIPTION**: Describe each discharge originating from this facility.

SEE ATTACHMENT 4

16. COMBINED TOTAL FLOW:

TOTAL: 0.10 MGD (for public notice)

DESIGN FLOW: 0.10 MGD (MUN.)

- 17. STATUTORY OR REGULATORY BASIS FOR EFFLUENT LIMITATIONS AND SPECIAL CONDITIONS: (Check all which are appropriate)
 - X State Water Control Law
 - X Clean Water Act
 - X VPDES Permit Regulation (9 VAC 25-31-10 et seq.)
 - X EPA NPDES Regulation (Federal Register)
 - X EPA Effluent Guidelines (40 CFR 133 or 400 471)
 - X Water Quality Standards (9 VAC 25-260-5 et seq.)
 - ____ Wasteload Allocation from a TMDL or River Basin Plan
- 18. **EFFLUENT LIMITATIONS/MONITORING**: Provide all limitations and monitoring requirements being placed on each outfall.

SEE TABLE II - ATTACHMENT 5

19. EFFLUENT LIMITATIONS/MONITORING RATIONALE: Attach any analyses of an outfall by individual toxic parameter. As a minimum, it will include: statistics summary (number of data values, quantification level, expected value, variance, covariance, 97th percentile, and statistical method); wasteload allocation (acute, chronic and human health); effluent limitations determination; input data listing. Include all calculations used for each outfall and set of effluent limits and those used in any model(s). Include all calculations/documentation of any antidegradation or antibacksliding issues in the development of any limitations; complete the review statements below. Provide a rationale for limiting internal waste streams and indicator pollutants. Attach chlorine mass balance calculations, if performed. Attach any additional information used to develop the limitations, including any applicable water quality standards calculations (acute, chronic and human health).

OTHER CONSIDERATIONS IN LIMITATIONS DEVELOPMENT:

<u>VARIANCES/ALTERNATE LIMITATIONS</u>: Provide justification or refutation rationale for requested variances or alternatives to required permit conditions/limitations. This includes, but is not limited to: waivers from testing requirements; variances from technology guidelines or water quality standards; WER/translator study consideration; variances from standard permit limits/conditions.

N/A

SUITABLE DATA: In what, if any, effluent data were considered in the establishment of effluent limitations and provide all appropriate information/calculations.

All suitable effluent data were reviewed.

ANTIDEGRADATION REVIEW: Provide all appropriate information/calculations for the antidegradation review.

The receiving stream has been classified as tier 1; therefore, no further review is needed. Permit limits have been established by determining wasteload allocations that will result in attaining and/or maintaining all water quality criteria that apply to the receiving stream, including narrative criteria. These wasteload allocations will provide for the protection and maintenance of all existing uses.

ANTIBACKSLIDING REVIEW: Indicate if antibacksliding applies to this permit and, if so, provide all appropriate information.

There are no backsliding issues to address in this permit (i.e., limits as stringent or more stringent when compared to the previous permit).

SEE ATTACHMENT 6

20. **SPECIAL CONDITIONS RATIONALE**: Provide a rationale for each of the permit's special conditions.

SEE ATTACHMENT 7

21. TOXICS MONITORING/TOXICS REDUCTION AND WET LIMIT SPECIAL CONDITIONS RATIONALE:

Provide the justification for any toxics monitoring program and/or toxics reduction program and WET limit; the actual conditions for the permit are to be included under Attachment 6.

N/A

22. **SLUDGE DISPOSAL PLAN:** Provide a description of the sludge disposal plan (e.g., type sludge, treatment provided and disposal method). Indicate if any of the plan elements are included within the permit.

Sludge is dewatered by sludge press and incinerated. Ash is hauled to the landfill. This plan has been included in the VPDES application for approval. Standard special conditions are included in Part I of the permit.

23. MATERIAL STORED: List the type and quantity of wastes, fluids, or pollutants being stored at this facility. Briefly describe the storage facilities and list, if any, measures taken to prevent the stored material from reaching State waters.

NONE.

24. RECEIVING WATERS INFORMATION: Refer to the State Water Control Board's Water Quality Standards [e.g., River Basin Section Tables (9 VAC 25-260-5 et seq.). Use 9 VAC 25-260-140 C (introduction and numbered paragraph) to address tidal waters where fresh water standards would be applied or transitional waters where the most stringent of fresh or salt water standards would be applied. Attach any memoranda or other information which helped to develop permit conditions (i.e. tier determinations, PReP complaints, special water quality studies, STORET data and other biological and/or chemical data, etc.

SEE ATTACHMENT 8

25. <u>303(d) Listed Segments</u>: Indicate if the facility discharges to a segment that is listed on the current 303(d) list and, if so, provide all appropriate information/calculations.

This facility discharges directly to the Chesapeake Bay. This receiving stream segment has been listed on Part 1A of the 303(d) list for non-attainment of nutrients. A TMDL has not been prepared or approved for this stream segment. The permit contains a TMDL reopener clause which will allow the it to be modified, in compliance with section 303(d)(4) of the Act once a TMDL is approved.

SEE ATTACHMENT 8

26. CHANGES TO PERMIT: Use TABLE III(a) to record any changes from the previous permit and the rationale for those changes. Use TABLE III(b) to record any changes made to the permit during the permit processing period and the rationale for those changes [i.e., use for comments from the applicant, VDH, EPA, other agencies and/or the public where comments resulted in changes to the permit limitations or any other changes associated with the special conditions or reporting requirements].

SEE ATTACHMENT 9

27. NPDES INDUSTRIAL PERMIT RATING WORKSHEET:

N/A - This is a municipal facility.

28. **DEQ PLANNING COMMENTS RECEIVED ON DRAFT PERMIT**: Document any comments received from DEQ planning.

The discharge is not addressed in any planning document but will be included when the plan is updated.

29. **PUBLIC PARTICIPATION:** Document comments/responses received during the public participation process. If comments/responses provided, especially if they result in changes to the permit, place in the attachment.

VDH/DSS COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from the Virginia Dept. of Health and noted how resolved.

The VDH waived the right to comment and/or object to the adequacy of the draft permit.

EPA COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from the U.S. Environmental Protection Agency and noted how resolved.

EPA waived the right to comment and/or object to the adequacy of the draft permit.

ADJACENT STATE COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from an adjacent state and noted how resolved.

Not Applicable.

OTHER AGENCY COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from any other agencies (e.g., VIMS, VMRC, DGIF, etc.) and noted how resolved.

Not Applicable.

OTHER COMMENTS RECEIVED FROM RIPARIAN OWNERS/CITIZENS ON DRAFT PERMIT: Document any comments received from other sources and note how resolved.

The application and draft permit have received public notice in accordance with the VPDES Permit Regulation, and no comments were received.

Start Date **9/29**, 2009 End Date **9/29**, 2009

Persons may comment in writing or by e-mail to the DEQ on the proposed reissuance of the permit within 30 days from the date of the first notice. Address all comments to the contact person listed below. Written or e-mail comments shall include the name, address, and telephone number of the writer, and shall contain a complete, concise statement of the factual basis for comments. Only those comments received within this period will be considered. The Director of the DEO may decide to hold a public hearing if public response is significant. Requests for public hearings shall state the reason why a hearing is requested, the nature of the issues proposed to be raised in the public hearing and a brief explanation of how the requestor's interests would be directly and adversely affected by the proposed permit action.

All pertinent information is on file and may be inspected, and arrangements made for copying by contacting Robert E. Smithson at: Department of Environmental Quality (DEQ), Tidewater Regional Office, 5636 Southern Boulevard, Virginia Beach, VA 23462. Telephone: 757-518-2106 E-mail: robert.smithsonjr@deq.virginia.gov

Following the comment period, the Board will make a determination regarding the proposed reissuance. This determination will become effective, unless the Director grants a public hearing. Due notice of any public hearing will be given.

ADDITIONAL FACT SHEET COMMENTS/PERTINENT INFORMATION: 30.

Nutrient monitoring and nutrient concentration limitations: annual load limitations are covered in Tangier's nutrient general permit. Since the town does not propose an upgrade to optimize nutrient removal, developing concentrations limitations at this time are not applicable to this reissuance. A nutrient reopener has been included as a special condition.

The facility utilizes dual ultraviolet (UV) banks for disinfection and chlorine feed as a backup in case of power failure. Therefore, chlorine limitations and language are in the permit in case of applicability.

Pursuant to the revised disinfection policy (9 VAC 25-260-170.B.) which states that Enterococci (saltwater) criteria is to be utilized in addition to fecal coliform criteria when shellfish waters exist. To meet this regulation, Enterococci limitations are included in this permit.

Fecal coliform monitoring for alternative disinfection (2 days/week for shellfish waters) was reduced in frequency with a 1997 permit modification/CO negotiation to 1/Week to reduce the contract laboratory costs incurred by the town. A good compliance history for this parameter in the past permit cycle justifies making no changes to this agreement.

Ammonia-N (NH3-N) is not needed based upon an estimate of available dilution from the Chesapeake Bay, however nutrient monitoring every two weeks will be required via the nutrient general permit for dischargers to the Chesapeake Bay watershed. This general permit (VAN050004) was issued to comply with the Chesapeake Bay Tributary Strategy to meet future nutrient goals for the Bay. A nutrient reopener will be included in this permit. A TMDL Reopener has also been included, should one be developed during the life of the permit and there be a need to incorporate new limitations as a result.

A D.O. limit of 4.0 mg/l minimum (WQS for Class II waters) is in the permit to protect water quality in the Bay.

Effluent monitoring reduction was considered per standard guidance. A compliance history since year 2005 was reviewed for qualification. Refer to fact sheet pages 72-84 for compliance review - facility does not qualify for monitoring reduction at this time.

ATTACHMENT 1

SITE INSPECTION REPORT

8

Virginia Department of Environmental Quality

WASTEWATER FACILITY INSPECTION REPORT

FACILITY NAME: Tangier Island	INSPECTION DATE: 5/	/15/2009
Wastewater Plan	The Young and the Control of the Con	ephen J. Thomas
PERMIT No.: VA0067423	REPORT DATE: 5.	/21/2009
TYPE OF FACILITY: ✓ Municipal ✓ Minor ✓ Industrial	TIME OF INSPECTION:	Arrival Departure 0:00 AM 1:45 PM
Federal	TOTAL TIME SPENT (including prep & travel)	Hours
PHOTOGRAPHS: Yes	UNANNOUNCED INSPECTION	N? ▼ Yes
l No		<u>.</u>
REVIEWED BY / Date: Kenneth Ti	Raum 6/25/09	
PRESENT DURING INSPECTION: CI	nris Pruitt, Garman Parks – Tangier Island illiams - DEQ	Sean Priest, Will

TECHNICAL INSPECTION

TECHNICAL INSPECTION	
Has there been any new construction? If so, were plans and specifications approved? Comments:	☐ Yes ☑ No
Is the Operations and Maintenance Manual approved and up-to-date? Comments: Did not Review due to time constraints	Г Yes
 Are the Permit and/or Operation and Maintenance Manual specified licensed operator being met? Comments: 	▼ Yes
4. Are the Permit and/or Operation and Maintenance Manual specified operator staffing requirements being met? Comments:	▼ Yes
5. Is there an established and adequate program for training personnel? <u>Comments:</u>	T Yes ▼ No
6. Are preventive maintenance task schedules being met? <u>Comments: Did not review all maintenance records, UV system records for last 3 months were reviewed.</u>	Yes No
7. Does the plant experience any organic or hydraulic overloading? <u>Comments:</u> Plant will experience hydraulic overloading during period of heavy rainfall or extreme high tide.	✓ Yes 「No
8. Has there been any bypassing or overflows since the last inspection? Comments:	✓ Yes ✓ No
9. Is the standby generator (including power transfer switch) operational and exercised regularly? Comments: Rackun power would be convelic to	▼ Yes 「No
Comments: Backup power would be supplied by a town generator that provides power to the entire island. 10. Is the plant alarm system operational and tested regularly?	·
Comments: N/A	TYes TNo

PROBLEMS INDENTIFIED AT THE LAST INSPECTION

1.	The sludge collection system is currently being operated for a brief period once per day on both the primary & secondary sedimentation basin. The installation of the timers would improve operations of both the basins. The sludge drives are now turned on & off manually.
	The sludge drives are now being operated twice a day on the units.
	The sludge press must be repaired. This is an essential component of the operation of the plant.
2.	The sludge press is now mechanically operational, but is still not being run. This problem has not been resolved.
3.	The fans and louvers in the treatment building need replacement. They are not operable at this time. The repair or replacement of the fans will provide much needed ventilation to the building.
	This problem has not been resolved.
	The UV panel is not functioning properly. It needs to be looked at by a qualified technician.
4.	This problem has not been resolved.
5.	The telescoping valve in the digester needs to be repaired.
 	This problem has not been resolved.
6.	The lighting in the plant should be improved. Some areas of the plant are dangerous and tough to work in because of the poor lighting. The cleaning of the light covers or cover replacement might provide additional lighting.
	This problem has not been resolved.
7.	Please provide additional information on the outcome of the smoke testing performed in April of this year and if all homeowners who had inflow problems have completed necessary repairs.
	This information has not been provided.

REQUIRED CORRECTIVE ACTIONS:

- 1. The sludge press needs to be operational. All required supplies and chemicals must be provided to insure the proper operation of the Unit. During the inspection it was evident the incineration unit is not operational and needs to be replaced. The current sludge disposal plan calls for all waste sludge to be incinerated. What are the disposal plans for any waste sludge that will be generated by the facility? Records on the amount of sludge produced and disposal method must be kept by the town.
- 2. The flow meter needs to be calibrated on a yearly basis. Last calibration on 2/1/2008.
- 3. The UV disinfection unit needs to be serviced by a qualified technician to insure proper operation. Please provide documentation when this service has been performed.
- 4. The telescoping valve for the digester needs to be repaired.


ATTACHMENT 2

DISCHARGE LOCATION/TOPOGRAPHIC MAP


TABLE I NUMBER AND DESCRIPTION OF OUTFALLS

OUTFALL NO.	DISCHARGE LOCATION	DISCHARGE SOURCE	TREATMENT (2)	FLOW (3)
001	37-49-40N 076-00-35W	Domestic waste from the Town of Tangier	Bar screening, primary settling, secondary biological treatment (RBC), secondary clarification, UV light disinfection, sludge conditioning and incineration.	0.10 MGD
	·	·		
	r			
			,	,
		·		

- (1) List operations contributing to flow
- (2) Give brief description, unit by unit
- (3) Give maximum 30-day average flow for industry and design flow for municipal



TOWN OF TANGIER WUTP 19




3-D TopoQuads Copyright © 1999 DeLorme Yarmouth, ME 04096


3 mi Scale: 1:500,000 Detail: 8-6 Datum: NAD27

19

ATTACHMENT 3

SCHEMATIC/PLANS & SPECS/SITE MAP/ WATER BALANCE





ATTACHMENT 5

TABLE II

EFFLUENT MONITORING LIMITATIONS

TABLE II - MUNICIPAL EFFLUENT LIMITATIONS/MONITORING

OUTFALL # 001 DESIGN FLOW: 0.10 MGD Outfall Description: Municipal STP Outfall for the Town of Tangier SIC CODE: 4952

(X) Final Limits Effective Dates	. 1	From: Permit	Issuance	To:	Permit Expiration	piration		
PARAMETER & UNITS	BASIS	DESIGN		EFFLUENT LIMITATIONS	IMITATIONS		MONITORING REQUIREMENTS	ENG SIVITS
	LIMITS	FLOW MULTIPLIER	MONTHLY	WEEKLY AVERAGE	MINIMUM	MAXIMUM	FREQUENCY	SAMPLE TYPE
Flow (MGD)[a]	ε,		NĽ	NA	NA	NL	Continuous	TI & RE*
рн (s.u.)	m		NA	NA	6.0	0.6	1/Day	Grab
BOD5 (mg/1)[d]	Н		30	45	NA	NA	1/W	4HC
BOD5 (kg/d)	-	0.10	17	17	NA	NA	1/W	4HC
TSS (mg/1)[d]	\leftarrow		30	45	NA	NA	1/W	4HC
TSS (kg/d)	\ \ 	0.10	11	17	NA	NA	1/W	4HC
TRC(mg/1)[b][d]	2	-	0.013	0.016	NA	NA	1/D	Grab
Fecal Coliform (N/CML)[b][c]	N		200	NA	NA	NA	1/W(Between 10 am & 4 pm)	Grab
Enterococci (N/CML)[b][c]	7		35	NA	NA	NA	1/W(Between 10 am & 4 pm)	Grab
	2	7-10-10-10-1	NA	NA	4.0	NL	1/D	Grab
Total Kjeldahl Nitrogen (as N) (mg/l) (kg/d) [d][e]	m		NL	NA	NA	NA	2/Month	4HC

*TI & RE = Totalizing, Indicating & Recording Equipment

NA = NOT APPLICABLE; NL = NO LIMIT, MONITORING REQUIREMENT ONLY

Upon issuance of the permit, Discharge Monitoring Reports (DMRs) shall be submitted to the regional office at the frequency required by the permit regardless of whether an actual discharge occurs. In the event that there is no discharge for the monitoring period, then "no discharge" shall be reported on the DMR.

This facility has Total Nitrogen and Total Phosphorus calendar year load limits associated with this outfall included in the current Registration List under registration number VANO50004, enforceable under the General VPDES Watershed Permit Regulation for Total Nitrogen and Total Phosphorus Discharges and Nutrient Trading in the Chesapeake Watershed in Virginia.

- See Part I.D.5. for exceeding 95% of the design capacity 3 months consecutively. See Part I.B. for additional monitoring instructions. **⊕ ⊡** ⊡ ⊇ ॼ
- Fecal coliform and enterococci monthly average is calculated as a geometric mean. See Parts I.D.6. and I.D.7. for quantification levels and reporting requirements, respectively. 2/Month = two samples taken during the calendar month, no less than two weeks apart.

The bases for the limitations codes are:

- 1. Technology (e.g., Federal Effluent Guidelines)
 2. Water Quality Standards (9 VAC 25-260 et. seq.)
 3. Best Professional Judgment

ATTACHMENT 6

EFFLUENT LIMITATIONS/MONITORING
RATIONALE/SUITABLE DATA/
ANTIDEGRADATION/ANTIBACKSLIDING

ATTACHMENT 6

VPDES PERMIT PROGRAM

Rationale for Effluent Limitations and Monitoring

Monitoring frequency for BOD5, TSS, fecal coliform and enterococci will be 1D/Week and monitoring for flow will be continuous. D.O. and, pH will be monitored daily. Effluent limitations are based upon federal effluent guidelines, best professional judgement and the water quality standards.

Disinfection is achieved by UV light with chlorine as backup in case of a power failure (TRC language added with this reissuance). Recent changes to the disinfection policy (9 VAC 25-260-170.B.) requires that Enterococci be used as the best indicator of adequate disinfection in saltwater. To meet this regulation, an Enterococci limit has been incorporated into this permit. A Fecal coliform limit will continue to be required for shellfish protection.

OUTFALL 001

Flow: No limit - BPJ; monitoring continuously with totalizing, indicating and recording equipment - standard requirement for a municipal permit with this design flow. This facility has a design flow of 0.1 MGD

pH: Minimum of 6.0 s.u., maximum of 9.0 s.u. - BPJ to protect water quality in the receiving stream; grab sample.

BOD5 & TSS: Monthly average limit of 30 mg/l (11 kg/d) and a weekly average limit of 45 mg/l (17 kg/d) were based upon federal effluent guidelines, 4 Hr. composite.

Fecal Coliform: WQS-200 n/cml: This limit has been assigned in accordance with 9 VAC 25-260-170 since this discharge is to shellfish waters; 1/week monitoring frequency was established with a 1997 permit modification/CO negotiation to reduce the contract laboratory costs incurred by the town (it typically would be monitored 2 days/week for standard "a"-shellfish). A good compliance history for this parameter in the past permit cycle justifies making no changes to the referenced CO agreement; grab sample

Enterococci: WQS-35 n/cml: This limit has been assigned to this permit in accordance with Guidance Memo No. 03-2007; grab sample

TRC - WQS-0.013 mg/l monthly average - 0.016 mg/l weekly average: This facility used UV for disinfection of effluent. Chlorine is very infrequently utilized at the facility as an emergency backup to the UV (power failure). The monitoring/limiting of chlorine is required during emergency use. Chlorine limitations were calculated as a toxic parameter in accordance with OWPS guidance and VPDES manual (See Attachment 6-2).

D.O. - WQS-limit 4.0 mg/l min. to protect Class II waters; monitoring 1/D - BPJ to protect water quality in the Bay; grab sample

Ammonia-N is not needed based upon an estimate of available dilution from the Chesapeake Bay. Given any kind of reasonable allowance for a _mixing zone, it becomes obvious that this small domestic STP (no industrial contributions) would not be expected to cause violations of the WQS in the Bay.). See Attachment 6: Memorandum from Dale Phillips. TKN will be monitored.

TKN Nutrient monitoring twice each month is required to comply with the Chesapeake Bay Tributary Strategy to meet future nutrient goals for the Bay; BPJ mg/l-kg/day: Monitoring in accordance with Guidance 04-2017*. See pages 82-90

CALCULATIONS

Loading (kg/d)= concentration (mg/l) X flow (MGD) X 3.785

BOD loading (monthly average) = 30 (mg/l) X 0.10 (MGD) X 3.785 = 11.35 kg/d = 11 kg/d (significant figures guidance) BOD loading (weekly average) = 45 (mg/l) X 0.10 (MGD) X 3.785 = 17.03 kg/d = 17 kg/d (significant figures guidance)

TSS loading (monthly average) = 30 (mg/l) X 0.10 (MGD) X 3.785 = $\frac{11.35 \text{ kg/d} = 11 \text{ kg/d}}{17.03 \text{ kg/d} = 17.03 \text{ kg/d}}$ (significant figures guidance)

7/9/04 4:53:54 PM

Facility = Tangier WWTP
Chemical = chlorine (CPO) mg/l
Chronic averaging period = 4
WLAa = 0.026
WLAc = 0.375
Q.L. = 0.1
samples/mo. = 30
samples/wk. = 7

Summary of Statistics:

observations = 4
Expected Value = 2.9
Variance = 3.0276
C.V. = 0.6
97th percentile daily values = 7.05691
97th percentile 4 day average = 4.82499
97th percentile 30 day average= 3.49755
< Q.L. = 0
Model used = BPJ Assumptions, type 2 data

A limit is needed based on Acute Toxicity
Maximum Daily Limit = 0.026
Average Weekly limit = 1.58783873755527E-02
Average Monthly Llmit = 1.28861502605596E-02

.015 mg/L Below detection .013 mg/L Level of .1 mg/L

The data are:

2.5 3.5

3

2.6

		<u>.</u>	70107	, 440										
Control Cont		Č	walta prio	Culer	Instream	<u> </u>	Antidegradatic	ا د		Water Qual	Ity		Antideorac	office
Acute Chronic Chieria Acute Chronic	,	S)	W)	Waters	Background		Baseline		Wa	ste Load Allo	cation	8	aste Load A	llocation
Price Pric		Acute	Chronic	Criteria	(Expected value*)	Acute	Chronic	Human	Acute	Chronic	<u> </u>	Acute	Chronic	A} Himan
Section Sect	thylbenzene			29000							Health			Health
1500 1500	onochloro-							2900			1450000			145000
Composition	Jenzene atrachloro			21000				2100			0.000			
Sectivities Section	thylene			3500						. 	000000			105000
Signature Sign	luene			200000				350			175000			17500
Since Sinc	ichloroethylene			810				20000			10000000			100000
ACIDS EXTRACTABLE S 265000 100	nyl Chloride			5300				81			40500			4050
ACIDS EXTRACT ABLES Acidom Acidom						1000		530			265000			26500
1500- 1500- 1500 1500-	Chlorophenol				Ĭ	SIDO E	XIKAC	IABLES	m					
13 7.9 8.2 2.30 3.25 1.975 8.2 2.6 3.95 4100 162.5 98.75 1.6070 1.2 1.6075 1.8	4 Dichloro-	1		400				40			20000			
13 7.9 82 8.2 8.2 8.2 8.2 8.2 8.1000 162.5 98.75 1.975 8.2 2.6 395 4100 162.5 98.75 1.6075 1.6075 1.875 2.1500 2.5 1.875 2.1500 1.2	henol			790	-						2002			2000
13 7.9 82 8.2 2.6 3.95 4100 162.5 98.75 1.975 1.975 8.2 2.6 3.95 4100 162.5 98.75 1.6075 1.875 1.875 2.1500 2.5 1.875 2.1500 2.5 1.875 2.1500 2.5 1.875 2.1500 2.5 1.875 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500 2.5 2.1500	4 Dimethyl-			3				79			39500	_		3950
13 7.9 82 8.2 26 395 4100 162.5 98.75 1670	enol	1		2300				Č						
richloro- 6.43 6.43 6.43 6.45 6.45 26 3.25 26 3.25 4.6000 6.5 3.25 4.6000 6.5 4.6000 6.5 4.6000 6.5 4.6000 6.5 7			7					0007			115000			11500
Figure F			2	4800000		3.25	1.975	8.2	56	395	4100	160 E	, 100	;
AISCELLANEOUS 3-N) 6.43 0.97	, 6-Trichloro-			200001				460000			230000000	200	80.73	9300000
AHSCELLANEOUS 12.86 48.5 0.2425 15.00 2.45 12.86 37.5 12.8 12.8 12.8 12.8 12.8 12.8 12.8 12.8	enol	1		65		<u> </u>		u u						2000000
3-N) 6.43 0.97 1.6075 0.2425 1.876 48.5 0.00 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0						MISCE	I ANIT				3250			325
3-N) 6.43 0.97 1.6075 0.2425 12.86 48.5 0 0 0 (CPO) 13 7.5 3.25 1.875 6.25 21500 7 50 162.5 93.75 1 1 1 215000 0.25 21500 7 50 10750000 12.5 12.5	nonia	-						200	ĺ	-			4	
(CPO) 13 7.5 3.25 1.875 21500 25 0.25 0.25 21500 25 50 10750000 12.5 12.5	-N)	43	0.97	-		1 8075								
(CPO) 13 7.5 3.25 1.875 21500 26 375 162.5 93.75 1.55 1.55 1.55 1.55 1.55 1.55 1.55 1	rides					6/00:1	0.2425		12.86	48.5		0	c	
1 1 215000 0.25 21500 Z 50 10750000 12.5 93.75 1.2	(CPO)	3	7.5			1000				(
1.2 0.25 21500 2 50 10750000 12.5 12.5		_	-	215000		3.20 0.25	1.875		26	(375)		162.5	93.75	
	án			1.2		0.40	0.25	21500)-	20	10750000	12.5	12.5	1075000

Waste Load Allocation Antidegradation Waste Load Allocation Water Quality Antidegradation Baseline Instream Background Other Surface Saltwater Criteria Parameter

E6

	=			T		T	<u></u>	7		Γ	T	T			7
	Ą	\$ 6 E	Health												
	(AD-WLA)	Chronic							25				_		
		1													
		Human Acute	Health										_		_
	(WQ-WLA)	Chronic			_			207	3				_		200
		Acute						-	 			 			0.72
ngier WW ⁻		Human	Health										_		_
racility: 10wn of Tangier WWTP		Chronic					_	0.5						0.0005	2,000,0
racility: 1		Acute			1									60.0	7
Data	1	(Expected value*)													
Waters	- Critorio		-												
(A		Chronic					٥	 					200	0.00	
(SW)		Acute							-				0.36	20.0	
	•		Fecal Coliform	(N/Cmt)	Foaming Agents	(as MBAS)	Hydrogen Sulfide	Nitrate	Sudente	Julate	Total Dissolved	Solids	ributyllin		

ANTIDEGREDATION CALCULATIONS/BASELINES (Saltwater)

All values in ug/I unless otherwise noted

Facility: Town of Tangier WWTP

	C. C.	Sartwater Criteria	Other	Instream Background		Antidegradation Baseline	ion		Water Quality	ity		Antidegradation	ıtion
	s)	(SW)	Waters	Data				M	waste Load Allocation (WQ-WLA)	ocation)	e _M	Waste Load Allocation (AD-WLA)	ocation
	Acute	Chronic		value*)	Acute	Chronic	Human	Acute	Chronic	Human	Acute	Chronic	Human
			-			METAIS	1			Health			Health
Antimony			4300		-	717							
Arsenic							430			215000			
Arsenic III	69	36						<u></u>					21500
Barium					17.25	6		138	1800		862 5	450	
Cadmium	43	9.3									2122	001	
Chromium III					10.75	2.325		98	465		527 E	7.7	
Chromium VI	1100	ç									5.755	110.25	
Copper	5.9	38			275	12.5		2200	2500		0.107		
Iron					1.475	0.95		11.8	190		00/20	625	
Lead	240	603									(3,75	47.5	
Manganese		3			99	2.325		480	465		0000		
Mercury	2.1	0,025	0.053	-							2000	116.25	
Nickei	75	83	2000		0.525	0.00625	0.0053	4.2	1 25	100			
Selenium	300	7.1	4000		18.75	2.075	460	150	115	2,00	26.25	0.3125	0.265
Silver	2.3	+	0001		75	17.75	1100	900	25.50	23000	937.5	103.75	23000
Zinc	95		1		0.575			38	0000	00000	3750	887.5	55000
	33	00			23.75	21.5		÷ 5			28.75		
					PFOTI	PESTICIOES	200	180	4300		1187.5	1075	
Aldrin	1.3	0.13	0.0014			JUE O/F	CBS	ĺ					
Chlorodane	60.0	0.004	0.0050		0.325	0.0325	0.00014	2.6	6.5	0.07	20.07		
Chorpyrifos	0.011	0.0056	60000		0.0225	0.001	0.00059	0.18	0.0	0.00	10.25	1,625	0.007
(Dursban)		}			0.00275	0.0014		0.022	0.28	0.530	1.125 0.137F	0.05	0.0295
000			0.0084		1						2	, 0.0	
DDE			0.0059		1		0.00084	-		0.42			
100	0.13	0.001	0.0059		1000	+	0.00059			0.295			0.042
					0.0325	0.00025	0.00059	0.26	0.05	0.206	100		0.0295

Facility: Town of Tangier WWTP

Acute 69	Criteria (SW)	Surface			Alludegradation	ر د	_	Carlo actachi	4			
		Waters	Background Data		Baseline		Wa	water Quality Waste Load Allocation	ry cation	× ×	Antidegradation Waste Load Allocation	ation location
	Chronic	Criteria	(Expected	7				(WC-WLA)			(AD-WLA)	(7)
1.0			value)	Acute	Chronic	Human	Acute	Chronic	Human	Acute	Chronic	Human
·	0.1				1000	l logil			Health			Health
					0.020			5			1.25	
	36			17.25	თ		138	1800		867 5	5	
Dieldrin 0.71	0 0040	,,,,,								0.5	0.4	
fan	0.00	9.0014		0.1775	0.000475	0.00014	1.42	0.005	70.0	1		
	0.0007	240		0.0085	0.002175	24	0.088	0.000	0.07	8.8/5	0,02375	0.007
	0.0023	0.81		0.00925	0.000575	0.081	0.000	0.433	00021	0.425	0.10875	1200
	0.01				0.0025	30.5	0.074	0.115	40.5	0.4625	0.02875	4.05
representor 0.053	0.0036	0.0021		0.01225	0.0023			0,5			0.125	
 .				0.01020	6000.0	0.00021	0.106	0,18	0.105	0.6625	0.045	0.0105
cyclonexane 0.16 (Lindane)	0.01	25		0.04	0.0025	. 2.5	0.32	0,5	1250	c	1070	
Kepone	0									1		125
Malathion	0.03											
Mirex	0				0.0075			1.5			1	
Parathion 95	98										0.3/5	
PCB-1242	0 03	110000		23.75	21.5		190	4300		107		
PCB-1254	200	0.00045			0.0075	0.000045		- F	5000	1187.5	1075	
PCB-1221	800	0.00045			0.0075	0.000045		5 4	0.000		0.375	0.00225
PCB-1232	0.03	0.000			0.0075	0.000045		<u>م</u>	0.000		0.375	0.00225
PCB-1248	0.03	0.00045			0.0075	0.000045		-	0.0223		0.375	0.00225
PCB-1016	30.0	0.00045			0.0075	0.000045		5 4	0.0225	1	0.375	0.00225
Toxaphene	500	0.00045			0.0075	0.000045			0.0225		0.375	0.00225
ichlor.	0.002	0.0075		0.0525	0.0005	0.00075	c c		0.0225		0.375	0.00225
pheoxy)						 	74.7		0.375	2.625	0.025	0.0375
propíonic acid	-						- "			- · · · · · · · · · · · · · · · · · · ·		
(Silvex)	,	···;·				•		,		_		



Alf values in ug/l unless otherwise noted

ANTIDEGREDATION CALCULATIONS/BASELINES (Saltwafer)

Acute Chronic Human Acute Health Acute Health 11000 0.049 0.	Parameter Sal	Saltwater	Other	Instream	racility	Facility: 10wn of Tangier WWTP	angier WW	77					
Chronic Criteria (Expected Acute Chronic Human Acute Human Acute Human Acute Human Acute Chronic Human Acute Chronic Chr	ਹੋਂ 🦭	iteria SW)	Surface Waters	Background Data		Annucegradatio Baseline	<u>c</u>	Was	Water Quality	y cation	Μ	Antidegrad	lation Ilocation
Chronic Acute Chronic Human Acute Human Acute Human Acute Human Acute Human Acute Human Acute Human			Criteria	(Expected					(WQ-WLA)			(AD-WL	A)
BASE NEUTRAL EXTRACTABLES Health	Acute	Chronic	-	value*)	Acute	Chronic	Human	Acute	Chronic	Human	Acute	Chronic	Human
270 135000 150000 10049 1550000 10049 1004	į			BASE	NFI ITD	AI EVT	Team C	Į.		Health			Health
0.049 135000 0.049 24.5 0.049 24.5 0.049 24.5 520 24.5 520 24.5 1200 24.5 1200 24.5 1200 24.5 1700 24.5 1700 60000 260 13000 11200 13000 11200 600000 11200 600000 11200 600000			2700			75 5	として	DLES				-	
11000 5500000			110000				270			135000			2000
0.049 24.5 0.049 24.5 520 24.5 520 260000 520 260000 0.049 24.5 1200 24.5 1200 600000 1700 600000 260 130000 1200 130000 12000 6000000 12000 6000000							11000			5500000			00001
0.049 24.5 0.049 24.5 0.049 24.5 520 24.5 0.049 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 85000 260 13000 1200 13000 1200 600000 1200 600000 1200 600000 5.9 2050			0.49										000000
0.049 24.5 0.049 24.5 520 24.5 520 260000 22,5 2 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 850000 130000 130000 1200 130000 1200 12000 260 130000 1200 6000000 1200 6000000							0.049			24.5		·	2.45
0.049 24.5 0.049 24.5 520 260000 0.049 24.5 1200 24.5 1200 24.5 1200 24.5 1200 24.5 1200 850000 130000 600000 12000 130000 5.9 5.9		,	0.49										6.43
520 24.5 520 260000 0.049 24.5 1200 24.5 1200 24.5 1200 600000 260 130000 260 130000 1200 6000000 260 130000 5.9 2050							0.049			24.5			(
520 24.5 520 260000 0.049 24.5 1200 24.5 1200 24.5 1200 600000 1700 850000 260 130000 260 130000 1200 6000000 260 130000 260 130000 260 130000 260 130000			0 49										2.45
520 24.5 620 260000 0.049 24.5 1200 60000 1700 850000 260 130000 260 130000 260 130000 5.9 2050							0.049			24.5			,
520 260000 0.049 24.5 1200 24.5 1200 24.5 1200 850000 260 130000 1200 130000 1200 130000 5.9 24.5 260 130000 12000 6000000 6000000 6000000			0.40							2			2,45
520 260000 0.049 24.5 1200 60000 1700 85000 260 13000 1200 13000 260 13000 1200 5.9			2				0.049		_	24 5			
520 260000 0.049 24.5 1200 24.5 1200 60000 1700 85000 260 13000 1200 600000 5.9 260			5200	- • -		-							2.45
0.049 24.5 1200 24.5 1700 600000 260 130000 260 130000 12000 6000000 5.9 5.9			0.49				520			26000			
0.049 24.5 1200 600000 1700 850000 260 130000 260 130000 12000 6000000 6000000 6000000							0.049			27 2			26000
24.5 1200 600000 1700 850000 260 130000 1200 130000 5.9 5.9			0.40			-				21			2,45
1200 600000 1700 850000 260 130000 260 130000 12000 130000 5.9 5.9		-	12000		1		0.049			24.5	_	_	-
260 130000 260 130000 260 130000 12000 130000 5.9 260		-		-			1200			80000			2.45
260 130000 260 130000 1200 130000 5.9 260			17000						 	2000			00009
260 130000 130000 130000 12000 6000000			3				1700		_	00000			,
260 130000 260 130000 12000 6000000 5.9 260		-	2600							Onnica			85000
260 130000 12000 6000000 5.9		-	2002	-			260		-	130000	-		-
260 130000 12000 6000000 5.9		<u></u>	2600						-	000000			13000
12000 6000000			12000				260		_	130000			
5.9	-		2002				12000		-	000000	1		13000
5.9			C C	-						000000			000009
			20			-	5.9			2050	_		

Facility: Town of Tangier WWTP

All values in ug/l unless otherwise noted

	Parameter	Saltwater	Other	Instream		100							
Waters Data Data Master Conformation Waster Conformation Waster Conformation Waster Load Allocation AD-WLA) 1001 Crifteria (Expected value) Acute (Expected value) Chronic Human Human Acute (ACCO) Chronic Human Acute (ACCO) Chronic Human Acute (ACCO) Chronic Human Acute (ACCO) Chronic Human Acute (ACCO) Chronic Human Acute (ACCO) Chronic Human Acute (ACCO) Acute (ACCO) Chronic Human Acute (ACCO) Acute (Criteria	Surface	Background		Andegradatio	Ę		Water Qualit	À		Antidegrad	ation
Oritina (Expected Acute Chronic Human Ac		(SW)	Waters	Data		baseline		Was	te Load Alloc	cation	Ň	aste Load A	llocation
STATE Value Value Pacute Chronic Human Acute Chronic Human Chronic Human Chronic Human Acute Chronic Human Chronic Hum		·	Criteria	(Expected					(V) (V) (V)			(AD-WL	A)
91 Health Health Pleatin Pleat				value*)	Acute	Chronic	Human	Acute	Chronic		Acute	Chronic	
97 91 4550 14000 1400 70000 0.49 1400 70000 490000 49000 24.5 1900 190 24.5 1900 190 24.5 1900 1100 55000 850 1100 55000 45 71 3550 45 2250 18000 45 470 23500 450 470 23500 460 470 23500 890 4550 23000 1700 1700 23000	2, 4-Dinitro						Health				3		Health
370 37 4550 14000 1400 70000 0.49 24.5 24.5 490000 49000 2450000 11000 1100 55000 11000 1100 55000 350 71 4750 45 25500 71 45 2550 70 45 470 285000 45 470 23500 460 460 80000 480 480 4850 17000 89 49500	tolulene		9										
14000 1400 1400 16000	Fluoranthene	,	370				9.1			4550			455
1400 1400 1400 170000 140000 140000 140000 14000 140000 140000 140000 140000 140000 14000	Finorene		14000				37			18500			1850
0.49 0.049 24.5 49000 49000 24.5 190 190 95000 1100 55000 55000 710 71 35500 45 71 18000 45 2250 5700 5700 285000 1600 1600 285000 460 46 23500 990 48 48500 1700 1700 85000	Indeno (1, 2, 3-					1	1400			700000			20000
490000 24.5 1900 49000 24.5 1100 1100 55000 1100 95 47500 710 71 35500 45 71 35500 45 47500 18000 45 4750 2250 5700 470 23500 1600 46 23500 46 46 23500 990 49500 43500 1700 1700 850000	cd) pyrene		0.49		· ·· ·		:						9000
1900 490000 2450000 11000 55000 95000 710 95 47500 3800 380 45 45 45 45 285000 7 450 45 285000 7 460 460 460 460 88000 1700 1700 88000 88000	Isophorone		490000				0.049			24.5			2 45
11000 1500 95 950000 95000 95000 950000 95000 95000 950000 95000 95000 950000 95000 95000 950000 95000 95000 950000 950000 95000 95000 950000 950000 95000 950000 950000 95000 9500000 950000 950000 9500000	Nitrobenzene		1900	,		1	49000			24500000			045000
950 1100 55000 710 71 47500 3600 360 47500 18000 45 470 2250 2250 460 46 23500 23500 460 46 23500 23500 460 46 23500 23500 460 460 460 460 460 17000 460 460 460 460 460 17000 460 <	Pyrene		11000				190			95000			2430000
950 95 47500 710 71 35500 45 45 2250 57000 470 2250 4700 470 22500 16000 460 46 460 46 46 990 46 49500 17000 1700 850000	1, 2, 4 Trichloro-		000			Ŧ	1100			550000			9500
710 71 72	penzene		050		-		-			2000			22000
710 VOLATILES 3600 3500 15000 16000 1	-						ı			47500	·		4750
710 71 35500 180000 45 4.5 2250 2250 57000 5700 285000 800000 4700 470 23500 800000 460 46 23000 800000 990 49500 49500 49500 17000 1700 850000 850000	Benzene				<u>5</u> >	LAIILES	'n						2
3600 71 35500 45 4.5 180000 57000 5700 2250 4700 470 285000 16000 470 285000 460 1600 80000 990 99 4950 17000 85000 85000	Bromoferm		710				7.7						
45 4.5 180000 180000 57000 5700 2250 2250 4700 470 285000 235000 16000 1600 800000 235000 460 46 800000 23000 990 99 4950 49500 17000 1700 850000	al utiloloriti		3600			1	+			35500			2850
45 4.5 2250 57000 5700 2850000 4700 470 285000 16000 1600 80000 460 46 80000 990 99 49500 17000 1700 850000	Carbon						360			180000			3330
57000 4.5 2250 4700 2850000 2850000 16000 1600 800000 460 46 800000 990 99 49500 17000 850000	Tetrachloride		45										18000
57000 5700 2850000 4700 470 235000 16000 1600 800000 460 46 800000 990 99 49500 17000 85000	Chlorodibromo-		2				4.5			2250			
4700 5700 2850000 16000 470 235000 460 46 800000 990 99 49500 17000 1700 850000	methane		57000										977
16000 460 46 235000 460 46 23000 990 99 49500 17000 85000	Chloroform		4700				5700			2850000		_	0
460 46 800000 990 99 49500 17000 1700 850000	Dichloromethane		16000				470			235000			000007
460 46 23000 990 99 49500 17000 1700 850000	Dichlorobromo-						1600			800000	+		00007
990 99 46 23000 17000 99 49500 17000 850000	methane		460										80000
990 99 49500 17000 1700 850000	1, 2-Dichloro-						46			23000			
99 49500 17000 1700	ethane		_ U66								+		7300
17000 850000	1, 1-Dichloro						66			49500			
1700	ethylene		17000	-							-		4950
	All values in ug/l unles	ss otherwise noted					1700			850000		_	טטטצא

COL IONWEALTH OF VIR NIA D.O. & Ammonia

DEPARTMENT OF ENVIRONMENTAL QUALITY

P.O. & Ammonia

P.O. & Ammonia

Water Division

4900 Cox Road Glen Allen, Virginia 23060

MEMORANDUM

subject: Tangier Island WLA

To: Bob Goode, TRO

From: M. Dale Phillips

Date: May 23, 1994

Copies: Fred Holt

The dilution available for the Tangier Island STP is extremely high. I have no models that will yield a very accurate result but conservative assumptions and approximations result in estimated dilutions on the order of 500:1 to 1000:1 at locations near the discharge point. Given any kind of reasonable allowance for a mixing zone, it becomes obvious that this small domestic STP cannot cause violation of the water quality standards in the Chesapeake Bay unless the concentrations of materials are hundreds of times higher than could reasonably be expected or that have been observed in similar STPs. Indeed, this STP by itself can have no calculatable effects on the water quality in the bay outside of a small mixing zone.

Unless there is an industrial or other contributor having high concentrations of toxic materials, I believe that monitoring this discharge for toxic materials would be a waste of time and effort. I would not expect to find anything in the effluent at concentrations that would be sufficiently high to require limits or even concern. You should however make the final decision based on your more detailed knowledge of the sources of waste to the system.

Relative to antidegradation, things get a little confusing when the bay is being discussed. There are documented violations of the D.O. standard in the deep trenches of the central bay (D.O. approaches or reaches zero). In my opinion, these are natural occurrences and they could be expected regardless of the pollution reaching the bay. However, I believe that they are definitely increased in both extent and duration by the general pollution reaching the bay. There has been a lot of discussion relative to unacceptable water quality in the bay (SAVs, fisheries depletion, etc.) but I know of no other actual documented violation of a numerical water quality standard outside of mixing zones. Since either tier 1 or tier 2 could be justified, I will make no recommendation relative to antidegradation but will offer the following observations for your assistance:

a. If the bay is classified as tier 1 then, according to the antidegradation standard and guidance, it can be allowed to reach the maximum concentrations specified in the numerical water quality standards for all materials. This may not be



a bad choice since the Chesapeake Bay Program exists to define and obtain the desirable water quality in the bay and its recommendations may override all other considerations.

b. If the bay is classified as tier 2 then, baselines will have to be identified and antidegradation requirements will have to become part of the WLA procedure for major STPs directly affecting the bay. This may be somewhat difficult because the large database that exists does not include most toxic materials for which standards exist.

Recommendations:

I would recommend permit limits based on secondary treatment or its equivalent as required by regulation.

Water quality based limits for toxic materials are not needed based on an estimate of available dilution.

I would recommend that the special monitoring condition be omitted from this permit unless you have reason to suspect unusually high concentrations of a toxic material.

I will make no recommendations regarding the appropriate antidegradation tier of the bay but would note that, however it is decided, it will not modify the recommendations above.

These recommendations are specifically for the small Tangier Island STP discharging directly to the central Chesapeake Bay. They cannot be generalized or extrapolated to apply to any other facility or location.

ATTACHMENT 7 SPECIAL CONDITIONS RATIONALE

VPDES PERMIT PROGRAM LIST OF SPECIAL CONDITIONS RATIONALE

Attachment 7

B. Additional Total Residual Chlorine (TRC)/Enterococci Limitations and Monitoring Requirements

Rationale: Required by Water Quality Standards, 9VAC 25-260-170, Fecal coliform bacteria; other waters. Also, 40 CFR 122.41(e) requires the permittee, at all times, to properly operate and maintain all facilities and systems of treatment in order to comply with the permit. This ensures proper operation of chlorination equipment to maintain adequate disinfection.

Required by Water Quality Standards, 9 VAC 25-260-170.A.2.: new bacterial standards. These standards became effective as of January 15, 2003, as did the revised disinfection policy of 9 VAC 25-260-170.B. The disinfection policy of 9 VAC 25-260-170.B. requires that all effluents attain the applicable bacteria concentration stated in 9 VAC 25-260-170.A.2. prior to discharge.

- C. OTHER REQUIREMENTS OR SPECIAL CONDITIONS
- C.1. Permit Reopeners
 - a. Sludge Reopener

Rationale: Required by the VPDES Permit Regulation, 9 VAC 25-31-220 C., and 40 CFR 122.44 (c)(4), which note that all permits for domestic sewage treatment plants (including sludge-only facilities) include any applicable standard for sewage sludge use or disposal promulgated under section 405(d) of the Clean Water Act.

b. Nutrient Reopener

Rationale: 9 VAC 25-40-70.A. authorizes DEQ to include technology-based annual concentration limits in the permits of facilities that have installed nutrient control equipment, whether by new construction, expansion or upgrade. 9 VAC 25-31-390. A. authorizes DEQ to modify VPDES permits to promulgate amended water quality standards.

c. Water Quality Standards Reopener

Rationale: The VPDES Permit Regulation, 9 VAC 25-31-220 D requires effluent limitations to be established which will contribute to the attainment or maintenance of water quality criteria.

d. Total Maximum Daily Load (TMDL) Reopener

Rationale: For specified waters, section 303(d) of the Clean Water Act requires the development of total maximum daily loads necessary to achieve the applicable water quality standards. The TMDL must take into account seasonal variations and a margin of safety. In addition, section 62.1-44.19:7 of the State Water Control Law requires the development and implementation of plans to address impaired waters, including TMDLs. This condition allows for the permit to be either modified or, alternatively, revoked and reissued to incorporate the requirements of a TMDL once it is developed. In addition, the reopener recognizes that, in according to section 402(o)(1) of the Clean Water Act, limits and/or conditions may be

VPDES PERMIT PROGRAM LIST OF SPECIAL CONDITIONS RATIONALE

Attachment 7 continued

either more or less stringent than those contained in this permit. Specifically, they can be relaxed if they are the result of a TMDL, basin plan or other wasteload allocation prepared under section 303 of the Act.

D.2. Licensed Operator Requirement

Rationale: The Permit Regulation, 9 VAC 25-31-200 D and Code of Virginia 54.1-2300 et. seq., Rules and Regulations for Waterworks and Wastewater Works Operators (18 VAC 160-20-10 et seq.) requires licensure of operators.

D.3. Reliability Class

Rationale: Required by Sewage Collection and Treatment Regulations, 12 VAC 5-581-20 and 120 for all municipal facilities.

D.4. CTC, CTO and O & M Manual Requirements

Rationale: Required by the State Water Control Law, Section 62.1-44.19; the Sewage Collection and Treatment Regulations (12 VAC 5-581 et seq); Section 401 of the Clean Water Act; 40 CFR 122.41(e); and the VPDES Permit Regulation (9 VAC-25-31-190E).

D.5. 95% Design Capacity Notification

Rationale: Required by the VPDES Permit Regulation, 9 VAC 25-31-200 B.2. for all POTW and PVOTW permits. Best professional judgement is used to apply this condition to other (private) municipal treatment facilities.

D.6. Quantification Levels Under Part I.A.

Rationale: States are authorized to establish monitoring methods and procedures to compile and analyze data on water quality, as per 40 CFR part 130, Water Quality Planning and Management, subpart 130.4. Section b. of the special condition defines QL and is included per BPJ to clarify the difference between QL and MDL.

D.7. Compliance Reporting Under Part I.A.

<u>Rationale</u>: Defines reporting requirements for toxic parameters with quantification levels and other limited parameters to ensure consistent, accurate reporting on submitted reports.

D.8 Indirect Dischargers

Rationale: Required by VPDES Permit Regulation, 9 VAC 25-31-200 B.1. for POTWs and PVOTWs that receive waste from someone other than the owner of the treatment works.

VPDES PERMIT PROGRAM LIST OF SPECIAL CONDITIONS RATIONALE

Attachment 7 continued

D.9. Sludge Management Plan

Rationale: The VPDES Permit Regulation, 9 VAC 25-31-420, and 40 CFR 503.1 specify the purpose and applicability for sludge management plans. The VPDES Permit Regulation, 9 VAC 25-31-100 J.4., also sets forth certain detailed information which must be included in a sludge management plan. The VPDES sewage sludge permit application form and its attachments constitute the sludge management plan and will be considered for approval with the VPDES permit. In addition, the Biosolids Use Regulation, 12 VAC 5-585-330 and 340, specifies the general purpose and control requirements for an O&M manual in order to facilitate proper O&M of the facilities to meet the requirements of the regulation.

VPDES PERMIT PROGRAM LIST OF SPECIAL CONDITIONS RATIONALE continued...



Name of Condition:

Note: The following condition, typically included in POTW permits with flows greater than 40,000 GPD, is not deemed necessary since there are no industrial users on the island.

Significant Discharger Survey

Rationale: The VPDES Permit Regulation, 9 VAC 25-31-800 F.2.a., and 40 CFR 403.8 (f)(2)(i) require POTWs to identify and locate all possible industrial users which might be subject to the POTW pretreatment program.

ATTACHMENT 8


RECEIVING WATERS INFO TIER DETERMINATION/303 (D) LISTING

Department of Environmental Quality Tidewater Regional Office

5636 Southern Boulevard
Virginia Beach, VA 23462
SUBJECT: VPDES Application Re-
· · · · · · · · · · · · · · · · · · ·
The SMITHS AND THE
DATE: 6/25/09
COPIES: TRO File facility #580, PPP
An and I
An application has been received for the following facility:
Facility Names Tours
Topo Map Name: Jangier Island /43 C Jangier WW7P
Receiving Stream: Chesapeake Boug
[Must be provided for each outfall included in this request or request will be returned]
request will be returned]
Attached is a Tonograph:
Attached is a Topographic Map showing facility property boundaries and outfall location(s) for those included in this request. [MUST be
provided or request will be returned]
Attached is a stream data Request Form (if data is requested).
(if data is requested).
ne request the following information
1XTier Determination. Tier:
Tier Determination. Tier:
Not Please include a basis for the tier determination.
2. Velue tell comments on .
2. Veguetel Stream Data Requested for outfall(s) ["STREAM DATA RETRIEVAL REQUEST FORWARD TO SEE attachment 1
TORM MUST be completed to the
3. X Is this facility mentioned:
3. X Is this facility mentioned in a Management Plan? No Yes
No, but will be included when the Plan is well-
4X_ Are limits contained:
4X_ Are limits contained in a Management Plan?
No Yes (If Yes, Please include the basis for the limits.)
impaired (Category 5) stream segment?
6. X Are outfall(a)
6X Are outfall(s) WLAs contained in an approved TMDL?
No Yes (TE You To
No Yes (If Yes, Please include the WLAs)
Return Date Requested: 7/9/09
Date Returned: 7/9/09

Department of Environmental Quality Tidewater Regional Office

5636 Southern Boulevard	Virginia Beach, VA 23462
SUBJECT:	VPDES Application Requests
TO:	Planning Trayeie West, TRO
FROM:	B Smithson, TRO
DATE:	7/6/99
COPIES:	TRO File - facility # 580 , PPP
An applic	cation has been received for the following facility:
Low	n of Jangier WWTP
Topo Map	n of Jangier WWTP Name: Jangier Island 143C VPDES #: VADO 67423
. We reques	t the following information from you:
1. <u>X</u>	River Mile Determination for the smallest named water body into which this discharge flows.
2. <u>X</u>	Latitude/Longitude Confirmation. (If single outfall, outfall location; if multiple outfalls, center of facility.)
3.	STORET Data.
4.	Location of station(s) if STORET data are provided.
Attached	are the following:
1. <u>X</u>	River Mile Determination Form.
2. <u>X</u>	Topographic Map showing outfall location(s).
3.	STORET Request Form.
Return Du	10 Date: 7/20/99 Date Returned: 7/12/55
	River Mile: 7-CHE 061.00
*ALILI	
37 49 40	WHIER BODY IN: VAT. CIOE STORET SHABION: VAT. CIOE
075	5958 SECTION 2





2008 Impaired Waters

Category 4 & 5 by Cause Group Code*

Chesapeake Bay/Atlantic/Small Coastal Basins

Cause Group Code: C01E-17-PCB - Chesapeake Bay and Tidal Tributaries

Location:	Chesapeake Bay mainstem and its small coastal tidal tributaries
City/County	Accomack Co., Chesapeake Bay, Gloucester Co., Lancaster Co., Mathews Co., Middlesex Co., Norfolk City, Northampton Co., Northumberland Co., Poquoson City, Virginia Beach City, York Co.
Use(s):	Fish Consumption
Cause(s) / VA Category:	PCB in Fish Tissue / 5A

The Chesapeake Bay and its tidal tributaries are included under the 12/13/2004 VDH Fish Consumption Advisories for PCBs. No more than 2 meals/month are recommended of anadromous (coastal) striped bass.

The advisory was based on the results of DEQ's fish tissue monitoring program, which showed elevated PCBs levels in several monitoring sites within the basin, including:

2 sp at 7-GWR007.97 in the Great Wicomico River 1 sp. At 7-COC000 40 in Cockrell Creek

Also, VDH issued an additional separate fish consumption advisory on 12/13/2004 for PCBs in the Mobjack Bay and its tributaries, particularly the East, West, and Ware Rivers. No more than two meals/month of gizzard shad are recommended.

Chesapeake Ba	y and	Tidal	Tributaries
---------------	-------	-------	-------------

Estuary (sq. miles) Reservoir River (acres)

(miles)

Fish Consumption

PCB in Fish Tissue / 5A Total impaired size by water type:

1857.07

Sources:

Source Unknown

Attachment I-I



2008 Impaired Waters

Category 4 & 5 by Cause Group Code*

Chesapeake Bay/Atlantic/Small Coastal Basins

Cause Group Code: TANMH-DO-BAY - Chesapeake Bay segment TANMH (Tangier Sound)

Location:	This cause encompasses the complete CBP segment TANMH.
City/County	Accomack Co.
Use(s):	Aquatic Life, Open-Water Aquatic Life
Cause(s) / VA Category:	Oxygen, Dissolved / 5A, Oxygen, Dissolved / 5A

The 30-day dissolved oxygen criteria for open water use failed for the 2008 assessment. There is insufficient data to assess remaining shorter dissolved oxygen criteria for this use.

Chesapeake Bay segment TANMH (Tangier Sound)		Estuary (sq. miles)	Reservoir (acres)	River (miles)
Aquatic Life	Oxygen, Dissolved /5A Total impaired size by water type:	122.54		
4dRich discharge (a) + 2dRich discharge (a)	······································	CTCCTTNICEDIA	Market Annual Company	WATER TO THE PROPERTY OF THE PARTY OF THE PA
Open-Water Aquatic Life		Estuary (sq. miles)	Reservoir (acres)	River (miles)
	Oxygen, Dissolved / 5A Total impaired size by water type:	122.54		

Sources:

- Agriculture
- Atmospheric Deposition Nitrogen
- Industrial Point Source Discharge
- Internal Nutrient Recycling
- Loss of Riparian Habitat
- Municipal Point Source Discharges
- Sources Outside State Jurisdiction or Borders
- Wet Weather Discharges (Point Source and Combination of Stormwater, SSO or CSO)

Attachment 1-3



2008 Impaired Waters

Category 4 & 5 by Cause Group Code*

Chesapeake Bay/Atlantic/Small Coastal Basins

Cause Group Code: TANMH-SAV-BAY - Chesapeake Bay segment TANMH (Tangier Sound)

Location:	This cause encompasses the complete CBP segment TANMH.
City/County	Accomack Co.
Use(s):	Aquatic Life, Shallow-Water Submerged Aquatic Vegetation
Cause(s) / VA Category:	Aquatic Plants (Macrophytes) / 5A, Aquatic Plants (Macrophytes) / 5A

The acres of submerged aquatic vegetation (SAV) mapped through aerial surveys does not meet the criteria. There is insufficient data to assess the water clarity criteria.

Chesapeake Bay segment TANMH (Tangier Sound)		Estuary (sq. miles)	Reservoir (acres)	River (miles)
Aquatic Life	Aquatic Plants (Macrophytes) / 5A Total impaired size by water type:	122.54		
	TO CONTROL OF THE STATE OF THE		make	andre (althought), discourant , decourant
Shallow-Water Submerged Aquatic Vegetation		Estuary (sq. miles)	Reservoir (acres)	River (miles)
	Aquatic Plants (Macrophytes) / 5A Total impaired size by water type:	122.54		

Sources:

- Agriculture
- Atmospheric Deposition Nitrogen
- · Clean Sediments
- Industrial Point Source Discharge
- Internal Nutrient Recycling
- Loss of Riparian Habitat
- Municipal Point Source Discharges
- Sediment Resuspension (Clean Sediment)
- Sources Outside State Jurisdiction or Borders
- Wet Weather Discharges (Point Source and Combination of Stormwater, SSO or CSO)

Attachment 1-5

ATTACHMENT 9

TABLE III (a) & TABLE III (b) - CHANGE SHEETS

TABLE III(a)
VPDES PERMIT PROGRAM
Permit Processing Change Sheet

Effluent Limits and Monitoring Schedule: (List any changes FROM PREVIOUS PERMIT and give a brief rationale for the changes). ⊢

MONITORING LIMITS CHANGED EFFLUE FROM / TO	EFFLUENT LIMITS CHANGED FROM / TO	DATE & INITIAL
	CHANGE MADE:	DATE & INITIAL
Added loothote on elluent limits page in which there general permit with an associated watershed which ther general permit (WGP)	Guidance memo no. 27-2008 stipulates footnote in which there are no concentration limits or monitoring	60/90/L0
Added Nutrient Reopener and water quality standards (Guidan reopener the Chuldan the Chuldan permit	These reopeners were added per guidance (Guidance memo no. 27-2008) for facilities in the Chesapeake bay watershed and per VPDES permit manual, respectively.	60/90/10
Schedule of Compliance for enterococci removed from Schedu	Schedule was satisfied and limit is in place	60/90/10
Removed the following special conditions: Basis of applicable. Design, Interim Optimization Plan, nutrient reporting calculations	special conditions are no longer table.	60/90/20

TABLE III(b)

VPDES PERMIT PROGRAM Permit Processing Change Sheet

Effluent Limits and Monitoring Schedule: (List any changes MADE DURING PERMIT PROCESS and give a brief rationale for the changes). 1.

DATE & INITIAL RATIONALE EFFLUENT LIMITS CHANGED FROM / TO N/A MONITORING LIMITS CHANGED FROM / TO PARAMETER CHANGED OUTFALL NUMBER

DATE & INITIAL	
ΩH	
ТО:	
CHANGED	
Ü	
ZOM:	
OTHER CHANGES FROM:	
CHAN	
OTHER	

ATTACHMENT 10 EPA PERMIT CHECKLIST

Part I. Virginia Draft Permit Submission Checklist

In accordance with the MOA established between the Commonwealth of Virginia and the United States Environmental Protection Agency, Region III, the Commonwealth submits the following draft National Pollutant Discharge Elimination System (NPDES) permit for Agency review and concurrence.

Facility Na	me:	Town of Tangie	er WWTP				
NPDES Pe	ermit Number:	VA0067423					
Permit Writ	ter Name:	R. E. Smithson					
Date:		07/06/09					
Major []	Minor [X]	Industrial []	Municipal [X]	TMDL Relat	ed[]		
	A. Draft P	ermit Package Su	bmittal Includes:		Yes	No	N/A
1. Permit Ap	oplication?				Х		
	Draft Permit (fe		me permit – entire p	ermit,	Х		
	Public Notice?					Х	1
4. Complete	Fact Sheet?				Х		-
5. Priority Po	ollutant Screeni	ng to determine pa	rameters of concern	?	Х		
6. Reasonal	ble Potential an	alysis showing calc	culated WQBELs?		Х		
7. Dissolved	l Oxygen calcul	ations?				X	
8. Whole Eff	fluent Toxicity T	est summary and a	analysis?			X	
9. Permit Ra	ating Sheet for r	new or modified ind	ustrial facilities?				Х
					<u> </u>		<u> </u>

B. Permit/Facility Characteristics		No	N/A
1. Is this a new, or currently unpermitted facility?		Х	
2. Are all permissible outfalls (including combined sewer overflow points, non-process water and storm water) from the facility properly identified and authorized in the permit?	X		

B. Permit/Facility Characteristics cont	Yes	No	N/A
3. Does the record or permit contain a description of the wastewater treatment process?	Х		
4. Does the review of PCS/DMR data for at least the last 3 years indicate significant non-compliance with the existing permit?		Х	
5. Has there been any change in streamflow characteristics since the last permit was developed?		Х	
6. Does the permit allow the discharge of new or increased loadings of any pollutants?		Х	
7. Does the record or permit provide a description of the receiving water body(s) to which the facility discharges, including information on low/critical flow conditions and designated/existing uses?	Х		
8. Does the facility discharge to an impaired water (i.e., 303(d) listed water)?	Х		
9. Has a TMDL been developed and approved by EPA for the impaired water?		Х	
10. Does the record indicate that the TMDL development is on the State priority list and will most likely be developed within the life of the permit?		X	
11. Does the facility discharge a pollutant of concern identified in the TMDL?			Х
12. Have any limits been removed, or are any limits less stringent, than those in the current permit?		X	
13. Does the permit authorize discharges from Combined Sewer Overflows (CSOs)?		Х	
14. Does the permit allow/authorize discharge of sanitary sewage from points other than the POTW outfall(s) or CSO outfalls [i.e., Sanitary Sewer Overflows (SSOs) or treatment plant bypasses]?	•••	Х	
15. Does the permit authorize discharges of storm water?		Х	
16. Has the facility substantially enlarged or altered its operation or substantially increased its flow or production?		Х	
17. Are there any production-based, technology-based effluent limits in the permit?		Х	
18. Do any water quality-based effluent limit calculations differ from the State's standard policies or procedures?		X	
19. Are any WQBELs based on an interpretation of narrative criteria?		X	
20. Does the permit incorporate any variances or other exceptions to the State's standards or regulations?		Х	

B. Permit/Facility Characteristics cont	Yes	No	N/A
21. Does the permit contain a compliance schedule for any limit or condition?		Х	
22. Does the permit include appropriate Pretreatment Program requirements?			Х
23. Is there a potential impact to endangered/threatened species or their habitat by the facility's discharge(s)?		Х	
24. Have impacts from the discharge(s) at downstream potable water supplies been evaluated?			Х
25. Is there any indication that there is significant public interest in the permit action proposed for this facility?		Х	
26. Has previous permit, application, and fact sheet been examined?	X	 	

Part IIa. NPDES Draft Permit Checklist Region III NPDES Permit Quality Checklist – for POTWs

A. Permit Cover Page/Administration	Yes	No	N/A
Does the record or permit describe the physical location of the facility, including latitude and longitude (not necessarily on permit cover page)?	X		
2. Does the permit contain specific authorization-to-discharge information (from where to where, by whom)?	Х		

B. Effluent Limits – General Elements	Yes	No	N/A
1. Does the record describe the basis of final limits in the permit (e.g., that a comparison of technology and water quality-based limits was performed, and the most stringent limit selected)?	Х		
2. Does the record discuss whether "antibacksliding" provisions were met for any limits that are less stringent than those in the previous NPDES permit?			X

C. Technology-Based Effluent Limits (POTWs)	Yes	No	N/A
1. Does the permit contain numeric limits for <u>ALL</u> of the following: TSS, pH and BOD (or alternative, e.g., CBOD, COD, TOC)?	Х		
2. Does the permit require at least 85% removal for BOD (or BOD alternative) and TSS (or 65% for equivalent to secondary) consistent with 40 CFR Part 133?	Х	÷	
2.a. If no, does the record indicate that application of WQBELs, or some other means, results in more stringent requirements than 85% removal or that an exception consistent with 40 CFR 133.103 has been approved?			X
3. Are technology-based permit limits expressed in the appropriate units of measure (e.g., concentration, mass, SU)?	Х		
4. Are permit limits for BOD and TSS expressed in terms of both long term (e.g., average monthly) and short term (e.g., average weekly, daily maximum) limits?	Х		
5. Are any concentration limitations in the permit less stringent than the secondary treatment requirements (30 mg/l BOD5 and TSS for a 30-day average and 45 mg/l BOD5 and TSS for a 7-day average?		X	
5.a. If yes, does the record provide a justification (e.g., waste stabilization pond, trickling filter, etc.) for the alternate limitations?			Х

D. Water Quality-Based Effluent Limits	Yes	No	N/A
Does the permit include appropriate limitations consistent with 40 CFR 122.44(d) covering state narrative and numeric criteria for water quality?	X		
2. Does the record indicate that any WQBELs were derived from a completed and EPA approved TMDL?		Х	

D. Water Quality-Based Effluent Limits – cont.	Yes	No	N/A
3. Does the record provide effluent characteristics for each outfall?	Х		
Does the record document that a "reasonable potential" evaluation was performed?	X		
4.a. If yes, does the record indicate that the "reasonable potential" evaluation was performed in accordance with the State's approved procedures?	X		
5. Does the record describe the basis for allowing or disallowing in-stream dilution or a mixing zone?			Х
6. Does the record present WLA calculation procedures for all pollutants that were found to have "reasonable potential"?	Х		
7. Does the record indicate that the "reasonable potential" and WLA calculations accounted for contributions from upstream sources (i.e., do calculations include ambient/background concentrations)?			Х
8. Does the permit contain numeric effluent limits for all pollutants for which "reasonable potential" was determined?	X		
9. Are all final WQBELs in the permit consistent with the justification and/or documentation provided in the record?	X		
10. For all final WQBELs, are BOTH long-term (e.g., average monthly) AND short-term (e.g., weekly average, maximum daily, or instantaneous) effluent limits established?	Х		
11. Are WQBELs expressed in the permit using appropriate units of measure (e.g., mass, concentration)?	Х		-
12. Does the record indicate that an "antidegradation" review was performed in accordance with the State's approved antidegradation policy?	Х		

E. Monitoring and Reporting Requirements	Yes	No	N/A
Does the permit require at least annual monitoring for all limited parameters and other monitoring as required by State and Federal regulations?	X		
1.a. If no, does the record indicate that the facility applied for and was granted a monitoring waiver, AND, does the permit specifically incorporate his waiver?			X
Does the permit identify the physical location where monitoring is to be performed for each outfall?	X		



E. Monitoring and Reporting Requirements cont'd	Yes	No	N/A
3. Does the permit require at least annual influent monitoring for BOD (or BOD alternative) and TSS to assess compliance with applicable percent removal requirements?	X		
4. Does the permit require testing for Whole Effluent Toxicity (if applicable)?			X

F. Special Conditions	Yes	No	N/A
Does the permit include appropriate biosolids use/disposal requirements?	Х		
2. Does the permit include appropriate storm water program requirements?			Х
If the permit contains compliance schedule(s), are they consistent with statutory and regulatory deadlines and requirements?	X		
4. Are other special conditions (e.g., ambient sampling, mixing studies, TIE/TRE, BMPs, special studies) consistent with CWA and NPDES regulations?	Х		
5. For CSO facilities, does the permit require implementation of the "Nine Minimum Controls"?			Х
6. For CSO facilities, does the permit require development and implementation of a "Long Term Control Plan"?			X
7. For CSO facilities, does the permit require monitoring and reporting for CSO events?			X

G. Standard Conditions	Yes	No	N/A
Does the permit contain all 40 CFR 122.41 standard conditions or the State equivalent (or more stringent) conditions?	Х		

List of Standard Conditions - 40 CFR 122.41

Duty to comply
Duty to reapply
Need to halt or reduce activity
Not a defense
Duty to mitigate
Proper O & M
Permit actions

Property rights
Duty to provide information
Inspections and entry
Monitoring and records
Signatory requirement
Bypass
Upset

Reporting Requirements
Planned change
Anticipated noncompliance
Transfers
Monitoring reports
Compliance schedules
24-Hour reporting
Other non-compliance

2. Does the permit contain the additional standard condition (or the State	Х	
equivalent or more stringent conditions) for POTWs regarding notification of		
new introduction of pollutants and new industrial users [40 CFR 122.42(b)]?		

Part IIb. NPDES Draft Permit Checklist Region III NPDES Permit Quality Review Checklist – For Non-POTWs

N/A

A. Permit Cover Page/Administration		No	N/A
Does the record or permit describe the physical location of the facility, including latitude and longitude (not necessarily on permit cover page)?			
2. Does the permit contain specific authorization-to-discharge information (from where to where, by whom)?			

B. Effluent Limits – General Elements	Yes	No	N/A
1. Does the record describe the basis of final limits in the permit (e.g., that a comparison of technology and water quality-based limits was performed, and the most stringent limit selected)?			
2. Does the record discuss whether "antibacksliding" provisions were met for any limits that are less stringent than those in the previous NPDES permit?	177 (178)		

C. Technology-Based Effluent Limits (Effluent Guidelines & BPJ)	Yes	No	N/A
1. Is the facility subject to a national effluent limitations guideline (ELG)?			
1.a. If yes, does the record adequately document the categorization process, including an evaluation of whether the facility is a new source or an existing source?			
1.b. If no, does the record indicate that a technology-based analysis based on Best Professional Judgement (BPJ) was used for all pollutants of concern discharged at treatable concentrations?			
2. For all limits developed based on BPJ, does the record indicate that the limits are consistent with the criteria established at 40 CFR 125.3(d)?			
3. Does the record adequately document the calculations used to develop both ELG and /or BPJ technology-based effluent limits?			
4. For all limits that are based on production or flow, does the record indicate that the calculations are based on a "reasonable measure of ACTUAL production: for the facility (not design)?			
5. Does the permit contain "tiered" limits that reflect projected increases in production or flow?			
5.a. If yes, does the permit require the facility to notify the permitting authority when alternate levels of production or flow are attained?			
6. Are technology-based permit limits expressed in appropriate units of measure (e.g., concentration, mass, SU)?			

C. Technology-Based Effluent Limits (Effluent Guidelines & BPJ) cont	Yes	No	N/A
7. Are all technology-based limits expressed in terms of both maximum daily and monthly average limits?			
8. Are any final limits less stringent than required by applicable effluent limitations guidelines or BPJ?			

D. Water Quality-Based Effluent Limits	Yes	No	N/A
Does the permit include appropriate limitations consistent with 40 CFR 122.44(d) covering State narrative and numeric criteria for water quality?		-	
Does the record indicate that any WQBELs were derived from a completed and EPA approved TMDL?			
Does the record provide effluent characteristics for each outfall?			
4. Does the record document that a "reasonable potential" evaluation was performed?			
4.a. If yes, does the record indicate that the "reasonable potential" evaluation was performed in accordance with the State's approved procedures?			
5. Does the record describe the basis for allowing or disallowing in-stream dilution or a mixing zone?			
6. Does the record present WLA calculation procedures for all pollutants that were found to have "reasonable potential"?			
7. Does the record indicate that the "reasonable potential" and WLA calculations accounted for contributions from upstream sources (e.g., do calculations include ambient/background concentrations where data are available)?			
8. Does the permit contain numeric effluent limits for all pollutants for which "reasonable potential" was determined?			
9. Are all final WQBELs in the permit consistent with the justification and/or documentation provided in the record?			
10. For all final WQBELs, are BOTH long-term (e.g., average monthly) AND short-term (e.g., maximum daily, instantaneous) effluent limits established?			
11. Are WQBELs expressed in the permit using appropriate units of measure (e.g., mass concentration)?		-	
12. Does the record indicate that an "antidegradation" review was performed in accordance with the State's approved antidegradation policy?			

E. Monitoring and Reporting Requirements	Yes	No	N/A
1. Does the permit require at least annual monitoring for all limited parameters?			
1.a. If no, does the record indicate that the facility applied for and was granted a monitoring waiver, AND, does the permit specifically incorporate his waiver?			
2. Does the permit identify the physical location where monitoring is to be performed for each outfall?			
3. Does the permit require testing for Whole Effluent Toxicity in accordance with the State's standard practices (if applicable)?			

F. Special Conditions	Yes	No	N/A
Does the permit require development and implementation of a Best Management Practices (BMP) plan or site-specific BMPs?			
1.a. If yes, does the permit adequately incorporate and require compliance with the BMPs?			
2. If the permit contains compliance schedule(s), are they consistent with statutory and regulatory deadlines and requirements?			
3. Are other special conditions (e.g., ambient sampling, mixing studies, TIE/TRE, BMPs, special studies) consistent with CWA and NPDES regulations?			

G. Standard Condition	Yes	Yes No		
1. Does the permit contain all 40 CFR 122.41 sta equivalent (or more stringent) conditions?				
List of Standard Conditions – 40 CFR 122.41		<u> </u>		
Duty to comply Duty to reapply Need to halt or reduce activity not a defense Duty to mitigate Proper O & M Permit Actions Property rights Duty to provide information Inspections and entry Monitoring and reporting	Signatory requirement Reporting requirements Planned change Anticipated noncompliand Transfers Monitoring Reports Compliance schedules 24-hour reporting Other non-compliance Bypass Upset	e		
2. Does the permit contain the additional standard equivalent or more stringent conditions) for existin regarding pollutant notification levels [40 CFR 122]	g non-municipal dischargers			

Part III. Signature Page

Based on a review of the data and other information submitted by the permit applicant, and the draft permit and other administrative records generated by the Department and/or made available to the Department, the information provided on this checklist is accurate and complete, to the best of my knowledge.

Name R. E. Smithson

Title Environmental Engineer Sr.

Signature

Date /JULY 06, 2009

ATTACHMENT 11 CHRONOLOGY SHEET

Town of Tangier WWTP VA0067423

VPDES PERMIT PROGRAM

CHRONOLOGY OF EVENTS

APPLICATION RECEIVED	APPLICATION RETURNED	ADDITIONAL INFO REQUESTED	APPLICATION/ADD INFO	APPLICATION/ADD. INFO RECEIVED
06/17/09				
APPLICATION TO VI	H: 06/25/09	VDH -DSS CO	OMMENTS RECEIVED: 07/0	6/09
APPLICATION TO OW	PS: N/A	OWPS COMMEN	VTS RECEIVED:	
APPLICATION ADMIN	. COMPLETE: 07/06/09	APPLICATION	TECH. COMPLETE: 07/0	6/09

Date	DESCRIPTIVE STATEMENT [CHRONOLOGY OF EVENTS] (Meetings, telephone calls, letters, memos, hearings, etc. affecting permit from application to issuance)
06/17/09	Received application
06/23/09	Application reviewed for completeness; application complete
06/24/09	Application sent to planning for tier determination
07/06/09	DSS comments received, application complete
07/06/09	Draft permit/fact sheet developed
07/07/09	Application complete letter sent to permittee
07/19/09	planning responded with tier determination
07/ 13 /09	FS/DP routed for review
7/30/09	DP/FS sent to **********************************
7/31/09	Planning Comments rec
8/10/09	DP/FS APRIT SO ALLENES
7//	THE POINT TO SPOOT

ATTACHMENT 12

PUBLIC PARTICIPATION INFORMATION

ATTACHMENT 13

OTHER DOCUMENTS



DEPARTMENT OF ENVIRONMENTAL QUALITY

TIDEWATER REGIONAL OFFICE

L. Preston Bryant, Jr Secretary of Natural Resources 5636 Southern Boulevard, Virginia Beach, Virginia 23462 (757) 518-2000 Fax (757) 518-2103 www.deq.virginia.gov

David K. Paylo Director

Francis L. Daniel Regional Director

August 6, 2009

Ms. Renee Tyler, Town Manager Town of Tangier P. O. Box 244. Tangier, Va. 23440

RE:

VPDES Permit No. VA0067423 - Permit Reissuance

Town of Tangier Wastewater Treatment Plant, Tangier, VA

Dear Ms. Tyler:

The State Water Control Board is considering issuing the referenced permit modification. Please review the enclosed public notice and draft permit package carefully.

Certain public notice procedures must be complied with before the actual permit can be approved. They are as follows:

- 1. The attached public notice must be published once a week for two consecutive weeks in a newspaper of general local circulation. Please complete, sign, and return the attached authorization form which will allow us to mail the notice to the newspaper and allow the newspaper to bill you for the public notice.
- 2. A minimum of 30 days will be allowed for public response following the date of the first public notice. If no public response is received, or the public response can be satisfactorily answered, then the permit will be processed. However, if there is significant public response, then we may hold a public hearing. You will be advised if this occurs.

Please return the Public Notice Authorization as soon as possible so that we can continue processing your permit. If you have not submitted the authorization form within 14 days, permit processing will cease.

If you have any questions or comments on the draft permit or public notice requirements, please

contact me at (757) 518-2106.

Sincerely

Robert E. Smithson

Environmental Engineer Senior

Encl: Draft Permit and Fact Sheet

Public Notice

Public Notice Authorization Form

Cc:

DEQ TRO File # 580

AUTHORIZATION TO BILL APPLICANT FOR A PUBLIC NOTICE FOR TOWN OF TANGIER WWTP RE: PERMIT NO. VA0067423

I hereby authorize the Department of Environmental Quality to have the cost of publishing a public notice billed to the Agent/Department shown below. The public notice will be published once a week for two consecutive weeks in the:

	Eastern Shore News
Agent/Department to be billed:	Ms. Renee Tyler, Town Manager Town of Tangier P. O. Box 244. Tangier, Va. 23440
Applicant's Address:	Ms. Renee Tyler, Town Manager Town of Tangier P. O. Box 244. Tangier, Va. 23440
Agent's Telephone No:	
	Mastice OULEVARD
Authorizing Agent:	Print Name
Authorizing Agent's	Signature

VPDES Permit No. VA0067423 Town of Tangier WWTP, Tangier, VA

PUBLIC NOTICE OF AN ENVIRONMENTAL PERMIT

Citizens are invited to comment on a proposed permit that will allow the release of treated wastewater from a regulated municipal activity into a waterway in Tangier, Virginia

PUBLIC COMMENT PERIOD: Until 4:30 PM 30 days from the first date of this public notice (date to be inserted by newspaper)

PERMIT NAME: Virginia Pollutant Discharge Elimination System Permit. Owners or operators of facilities that discharge into Virginia waterways from a set location called a point source must apply for this permit.

NAME ADDRESS AND PERMIT NUMBER OF APPLICANT: Town of Tangier, P. O. Box 244, Tangier, Va. 23440; Permit No. VA0067423

NAME AND ADDRESS OF FACILITY: Town of Tangier Wastewater Treatment Plant, 7448 Wastewater Treatment Plant Road, Tangier, VA 23440

DISCHARGE LOCATION/RECEIVING STREAM/WATERSHED: Tangier, VA; discharge to the Chesapeake Bay- Chesapeake Bay, Atlantic Ocean and Small Coastal basin.

PROJECT DESCRIPTION: The Town of Tangier has applied to the Department of Environmental Quality (DEQ) for the reissuance of a permit for a treated domestic waste water discharge from the town's residences/businesses. The applicant proposes to discharge at a rate of 0.10 million gallons per day (MGD). The permit will limit the following pollutants to amounts that protect water quality: pH, biochemical oxygen demand, total suspended solids, dissolved oxygen, Enterococci, fecal coliform and total residual chlorine. Generated sludge will be incinerated. Nutrient monitoring is required.

TO COMMENT TO DEQ: via e-mail, fax or postal mail. You must include your name, address and telephone number plus the names and telephone numbers of any people you represent. DEQ must receive your comments during the comment period.

The public may review permit documents at the Tidewater Regional Office every work day by appointment. You may request a public hearing via e-mail, fax or postal mail during the comment period. Requests for hearings must include the reason for the hearing request, the nature of the issue(s) to be raised in the public hearing, your interest and how the facility affects you. DEQ may hold a public hearing, including another comment period, if public response is significant and there are substantial, disputed issues relevant to the permit.

CONTACT: Robert E. Smithson, DEQ Tidewater Regional Office, 5636 Southern Blvd. Va. Beach 23462. Tel: 757-518-2106; Fax: 757-518-2009. E-mail: robert.smithsonjr@deq.virginia.gov

MEMORANDUM

DEPARTMENT OF ENVIRONMENTAL QUALITY TIDEWATER REGIONAL OFFICE

2020	Soumern Bo	omevaru			virginia Beach, VA 65462	<u> </u>	
SUBJECT:		PLANNING STATEMENT COMMENTS FOR VPDES PERMIT NO. VA0067423					
		FAĊILITY: ACTION:	Town of Tangier WW REISSUE	/TP			
-		FACTYPE:	MUNICIPAL	•			
TO: FROM: DATE: DRAFTED BY: COPIES:		PLANNING Water Permits July 30, 2009 R. E. Smithson TRO File					
			Permit package [Applicate Polynomial Polynom		within 14 days from the date of	f the memo	
×	This facility is NOT MENTIONED in an existing Board adopted water quality management planning document applicable to the Cheasapeake Bay - Small Coastal - Eastern Shore River Basins						
	This facility will be included in the WQMP When the plan is updated.						
[]	This facility <u>IS MENTIONED</u> in the existing Board adopted water quality management planning documents for the						
	The facil	ity APPEARS T	O CONFORM with the	plans.			
[]	documen	lity <u>IS NOT IN (</u> ts applicable to t	the		pted water quality management	planning	
COMN	MENTS:						
	St	2 Den	A. Cio	ocio	7/31/09		



DEPARTMENT OF ENVIRONMENTAL QUALITY

L. Preston Bryant, Jr Secretary of Natural Resources TIDEWATER REGIONAL OFFICE 5636 Southern Boulevard, Virginia Beach, Virginia 23462 (757) 518-2000 Fax (757) 518-2103 www.deq.virginia.gov

David K. Paylor Director

Francis L. Daniel Regional Director

July 7, 2009

Ms. Renee Tyler, Town Manager Town of Tangier Wastewater Treatment Plant P. O. Box 244 Tangier, VA 23440

RE:

VPDES Permit Reissuance VA0067423

Town of Tangier Wastewater Treatment Plant

Tangier, VA

Dear Ms. Tyler:

Your application received June 17, 2009 has been reviewed and appears to be complete. Other reviews of the application will be required by state agencies to ensure that public health and the environment will be protected.

The next steps involve assembling the information necessary to develop the permit limitations and then drafting the permit. Once the draft permit is prepared and the appropriate reviews are performed, I will transmit the draft permit and supporting documentation to you for review.

Thank you for your cooperation in submitting the completed application. If you have any questions about our procedures or the status of your draft permit, please feel free to call me at (757) 518-2106.

Robert E. Smithson

Environmental Engineer Senior

cc: DEQ PPP File #580



Department of Health DIVISION OF SHELLFISH SANITATION

109 Governor Street, Room 614-B Richmond, VA 23219

Ph: 804-864-7487 Fax: 804-864-7481

RECEIVED - DEQ

MEMORANDUM

DATE:

7/1/2009

TO:

Robert E. Smithson, Jr.

Department of Environmental Quality

FROM:

Robert E. Croonenberghs, Ph.D., Director

Division of Shellfish Sanitation

SUBJECT: Town of Tangier Wastewater Treatment Plant

City / County: Accomack

Waterbody: Chesapeake Bay

Type: VPDES ☐ VMRC ☐ VPA ☐ VWP ☐ .IPA ☐ Other

- ,	Fer E William E Will E Will E Outer.
Аp	plication / Permit Number: VA0067423
	The project will not affect shellfish growing waters.
	The Division has no comments on the proposal. The project will involve <u>approved</u> shellfish growing waters, though a change in classification will not be required.
✓	The project is located in condemned shellfish growing waters and the activity, as described, will not cause an increase in the size or type of the existing closure.
	The project will affect condemned shellfish waters and will not cause an increase in the size of the total condemnation. However, a prohibited area (an area from which shellfish relay to approved waters for self-purification is not allowed) will be required within a portion of the currently condemned area. See comments.
	A buffer zone (including a prohibited area) has been previously established in the vicinity of this discharge, however, the closure will have to be revised. Map attached.
	This project will affect approved shellfish waters. If this discharge is approved, a buffer zone (including a prohibited area) will be established in the vicinity of the discharge. Map attached.
	Other

ADDITIONAL VDH-DSS conducts routine water quality monitoring in the vicinity of the site and would be required to respond COMMENTS: to any future degradation in water quality whether or not directly attributable to a specific source. If water quality were to deteriorate to a degree that does not meet the standard that exists at that time, then VDH-DSS would have to condemn the degraded area.





KAREN REMLEY, MD., M.B.A, F.A.A.P STATE HEALTH COMMISSIONER

J.WESLEY KLEENE, Ph. D., P.E. DIRECTOR, Office of Drinking Water

OFFICE OF DRINKING WATER

Southeast Virginia Field Office

830 Southampton Avenue Suite 2058 Norfolk, VA 23510 Phone (757) 683-2000

Fax (757) 683-2007

MEMORANDUM

Т	O:	

Robert E. Smithson, Jr.

DATE: 11N 2 9 2009

Environmental Engineer Senior

Department of Environmental Quality - Tidewater Regional Office

FROM:

Daniel B. Horne, P.E.

Engineering Field Director

CIT	Υ/	CO	UN	\mathbf{T}	\mathbf{Y} :

Accomack

PROJECT TYPE:

□ New

☑ Renewal or Revision

VPDES

□ VPA

☐ VWPP

□ ЈРА

☐ Other:

 \square

Number: VA 0067423

OWNER/APPLICANT: Tangier, Town of

PROJECT: Tangier, Town of

 \square There are no public water supply raw water intakes located within 15 miles downstream or within one tidal cycle upstream of the discharge.

The raw water intake for the

waterworks is located miles [downstream/upstream] of the discharge. This should be a sufficient distance to minimize the impacts of the discharge. We recommend a minimum Reliability Class of ____ for this facility.

The raw water intake for the waterworks is located [downstream/upstream (within one tidal cycle)] of the discharge.

Please forward a copy of the Draft Permit for our review and comment.

Comments:

Prepared by:

District Engineer

V.D.H. - Office of Drinking Water, Field Services Engineer

R:\DIST22\Accomack\DEQ Permits\VPDES etc Transmittal Memo Tangier.doc



Smithson, Robert

From: Smithson,Robert

Sent: Wednesday, June 24, 2009 3:17 PM

To: Horne, Daniel (VDH); Howell, Beth (MRC); Stagg, Ben (MRC); Skiles, Keith (VDH)

Cc: McConathy, James

Subject: Permit Application for Review-Permit #VA0067423, Town of Tangier WWTP, Tangier, VA

Attached is a link to the FTP site to access a permit application for your review. Under the folder for the facility listed above on the FTP site, there is a letter for each agency and the permit application. Please pull the information that you need off the FTP site. The letters and application will remain available for no longer than 30 days. If you have any issues with the FTP site or if you have any questions, please contact me.

ftp://ftp.deq.virginia.gov/wps/PERMIT/TRO/VDH,%20DSS,%20VMRC%20For%20Review/VA0067423%20Tangier%20WWTP

Smithson, Robert

From: Smithson, Robert

Sent: Monday, April 27, 2009 8:58 AM

To: 'Bryan Horton'

Cc: Augusta Co. Service Authority - Ken Fanfoni

Subject: FW: Tangier WWTP

FYI- central office concurs with TRO staff assessment: no design flow downgrade

From: Brockenbrough, Allan

Sent: Thursday, April 23, 2009 5:16 PM

To: Smithson, Robert

Cc: McConathy, James; Kennedy, John; Pollock, Alan; Cunningham, Frederick

Subject: RE: Tangier WWTP

Bob-

At this point I would advise against de-rating the permitted flow to start the process of getting Tangier out of the Water Quality Management Planning Regulation and out of the nutrient trading general permit. I base this on the following....

- I pulled Tangier flows out of CEDS and their average flows exceeded 0.1 MGD for eight months straight from Jun '07 thru Jan '08.
- There will hopefully be legislation introduced in the next session of the GA to allow Eastern Shore facilities to trade with other basins. I'm not sure if this will be on the agency's legislative agenda but the Exchange has expressed an interest in working with DEQ and the Eastern Shore legislators to make this happen. If this pans out then there will be more than enough credits for Tangier. Tangier can then make the choice whether it is more economical to purchase credits as an Exchange member or non-member.
- There has been substantial opposition to any increase in loads going into the Bay and de-rating the
 plant would be viewed as increasing previously approved loads. Other facilities that barely qualified as
 "significant" CB dischargers could follow suit.

Give me a call if you would like to discuss this further.

Allan

From: Smithson.Robert

Sent: Monday, April 20, 2009 11:50 AM

To: McConathy, James; Brockenbrough, Allan; Kennedy, John; Pollock, Alan

Subject: FW: Tangier WWTP

Gentlemen, see correspondence below. Reissuance application is due end of this month and they appear to be waiting on central office decision on how to proceed as far as what to submit. They obviously will be late in their submittal, as they are waiting on something from Allan and/or John?

From: Bryan Horton [mailto:bnhonan@msn.com]

Sent: Monday, April 20, 2009 11:22 AM

To: Smithson, Robert

Subject: FW: Tangier WWTP

Bob I have been waiting to hear info on this and was surprised when Ken forward the e- mail to me that you sent him. I was thinking it was not due to May as you will see in the e mails. Please let me know what you think is the best coarse of action I should take. Thanks Bryan.

Subject: RE: Tangier WWTP

Date: Mon, 20 Apr 2009 11:12:02 -0400

From: kfanfoni@co.augusta.va.us

To: bnhonan@msn.com

Hi Brvan.

The main question still was whether they would allow Tangier to ask for a reduction in design flow and if this would "remove" them from ENR or trading requirements. Would they allow a reduction to 0.095 MGD? Or would it have to be more significant, meaning having to worry about infringing on actual flow needs for the island?

Would they accept a request for extension, attaching John's email and saying that we are still waiting for DEQ to respond?

Or should you just send in a standard renewal request with a note that it may be modified pending a DEQ answer?

If you are concerned about the six month window for the application, we normally just let the permit writer know if we'll be late, and they are usually OK. You might try and email Bob, and I'd also mention waiting for DEQ since February.

From: Bryan Horton [mailto:bnhonan@msn.com]

Sent: Monday, April 20, 2009 10:52 AM

To: Ken Fanfoni

Subject: RE: Tangier WWTP

Ken I have been waiting to hear from you and forgot the due date was so close. I hope they do not hold that date to me I know you been waiting also. I have been working on my regional water plan. I do not know it I will be able to have all the info needed and to Renee to sign by this weekend. What can you do to help me out. I do not know why I thought this was due in May. Bryan

Subject: RE: Tangier WWTP

Date: Mon, 20 Apr 2009 10:43:11 -0400

From: kfanfoni@co.augusta.va.us

To: Robert.SmithsonJr@deq.virginia.gov

CC: James.McConathy@deq.virginia.gov; bnhonan@msn.com

Rop,

The last I heard was that I would be getting a response from DEQ prior to the submittal date. I'm not sure I've heard anything yet from anyone. See John's email below from 2/4/09. He mentioned that I would be getting a recommendation from DEQ. Maybe you can check internally and see what's up? Thanks.

Ken

From: Smithson, Robert [mailto:Robert.Smithson]r@deg.virginia.gov]

Sent: Monday, April 20, 2009 10:34 AM

To: Ken Fanfoni **Cc:** McConathy, James

Subject: FW: Tangier WWTP

Good morning Ken,

Just following up on Tangier's Reissuance application which is due April 28th to DEQ. Is everything on track for this submittal?

From: McConathy, James

Sent: Monday, April 20, 2009 10:27 AM

4/27/2009

To: Smithson, Robert

Subject: FW: Tangier WWTP

From: Augusta Co. Service Authority - Ken Fanfoni

Sent: Sunday, February 08, 2009 5:57 PM

To: Kennedy, John

Cc: Brockenbrough, Allan; McConathy, James; Pollock, Alan; Bryan Horton; tgitownoffice@yahoo.com

Subject: RE: Tangier WWTP

John.

Thanks for the reply and the contact info. I recognize the concerns with making a change like this, and I understand that DEQ has to consider all other consequences and how other permits would be impacted. If I can provide any information specific to the Tangier permit. I would be glad to talk with Allan or James. I think that one of the issues that might apply to Tangier versus other places is the fact that the Eastern Shore has such limited opportunities for nutrient trading or ny other practical options to meet the new rules. I would also expect the Chesapeake Bay Foundation to be very aware of what is going on with the Tangier permit, since they have their research station out there. But they should also recognize the reality of the minimal impact of the Tangier WWTP and the fact that they are essentially in compliance with the allocations. If a regulatory amendment could relieve the town of further administrative expenses, without actually impacting the bay in a negative way, perhaps everyone can come to some agreement.

Thanks.

Ken

From: Kennedy, John [mailto:jmkennedy@deq.virginia.gov]

Sent: Wednesday, February 04, 2009 9:04 AM

To: Ken Fanfoni

Cc: Brockenbrough, Allan; McConathy, James; Pollock, Alan

Subject: RE: Tangier WWTP

Ken - I've passed your email on to the Central Office Water Permit staff and they, in turn, have been corresponding with the Tidewater Regional Office Permit staff on this issue. The folks involved are Allan Brockenbrough in CO and James McCarthy in TRO.

According to TRO, the permit comes up for reissuance in Oct., so an application is expected in April. They should have a recommendation for you before the application is submitted but I can't say when exactly. There are concerns about setting a precedent to avoid the nutrient reduction requirements (there are several other plants "on the cusp" that might have benefited from a lower design flow rating), and the possibility of yielding a higher permitted design capacity (for the non-significant discharge rating below 100,000 gpd) that would give Tangier a higher nutrient allowance if they were to ever come back above the flow cutoff.

I suggest you deal directly with Allan and James in the future on this – I would only get involved if the approach is to reduce the flow rating and amend the Water Quality Mgmt Planning Regulation to remove Tangier from the significant discharger list.

John Kennedy

DEQ Chesapeake Bay Program

phone: 804-698-4312 fax: 804-698-4116

e-mail: jmkennedy@deq.virginia.gov

----Original Message----

From: Augusta Co. Service Authority - Ken Fanfoni

Sent: Monday, February 02, 2009 4:54 PM

To: Kennedy, John **Subject:** Tangier WWTP

Hi John.

It is time for the Tangier WWTP permit to be renewed. I asked Bob Smithson about amending their permit to de-rate their capacity so that they won't be subject to the Nutrient removal criteria. As you know, we have the issue of being slightly

over on TP, no one to trade with, and the extra costs of paying Exchange dues annually. They can easily give up some permitted capacity.

Bob said he didn't see how DEQ could allow this. I spoke to Alan Brockenbrough in Richmond, and he mentioned that this issue or email had found its way to his office, so I assume you also saw it. This was an issue we have talked about, but now I can't seem to get an answer from DEQ, and the application is due.

I suppose someone could go through the plant in detail and try to find some part that is not in full SCAT compliance and use that to justify changing the design flow, but I'd rather not go to that trouble.

Time is running short, and I'd be happy to come down to DEQ-Richmond and talk to whoever can make a decision on this. If they cannot modify their permitted flow, they will have to be in the trading game for the future, with additional costs that they would rather avoid. If you can suggest how I can move this forward, or who I should talk with, I will come down there as soon as practical to discuss it. I'd rather get the answers and decisions first hand. It's hard doing it all by email and phone.

Thanks,

Ken



COMMONWEALTH of VIRGINIA

DEPARTMENT OF ENVIRONMENTAL QUALITY

Preston Bryant Secretary of Natural Resources

TIDEWATER REGIONAL OFFICE 5636 Southern Boulevard, Virginia Beach, Virginia 23462 (757) 518-2000 Fax (757) 518-2103 www.deq.virginia.gov

October 20, 2008

David K. Paylor Director

Francis L. Daniel Regional Director

Ms. Renee Tyler, Town Manager Town of Tangier PO Box 244 Tangier, Virginia 23440

Re:

Reissuance of VPDES Permit No. VA0067423

Tangier WWTP, Tangier, VA

Dear Ms Tyler.

This letter is to remind you that your VPDES permit will expire on October 25, 2009.

If you wish to continue discharging, you must reapply for the permit. The State Water Control Board's VPDES Permit Regulation requires that we receive a complete application at least 180 days before the existing permit expires. The deadline for submitting the application is April 28, 2009. Early submissions are welcome and will better enable us to complete processing before permit expiration. The instructions and application forms are enclosed. The forms are also available online at the following address http://www.deg.virginia.gov/vpdes/permitfees.html.

If you would like to request a waiver from any of the sampling or testing requirements in the application forms, you must submit your application and a thorough justification for the request at least 240 days prior to the existing permit's expiration date. These waiver requests must be approved by DEQ and the U. S. EPA at least 180 days before the existing permit expires. DEQ will review your waiver request and, if it is justified, forward it to EPA. Failure to submit the waiver request by the 240-day deadline will result in the waiver being denied.

Upon completing the application, return the original and five copies to the Tidewater Regional Office at the above address. If you have the technology available however, we would prefer that the original signature application and a disk/CD or an e-mail with the application attached be submitted. This would eliminate the requirement of submitting five copies. We have also enclosed a pamphlet on Electronic DMR submittal and are encouraging all facilities to consider using this system for your DMR reporting.

There is no application fee associated with this re-issuance process. The legislature developed a new fee structure effective July 1, 2004, that eliminated application fees for VPDES and VPA permits. In place of the application fee, the new regulation imposes an annual permit fee. You will be billed by DEQ in the fall of each year.

fincerely

Please call me at (757) 518-2106 if you have any questions

Robert E. Smithson

Environmental Engineer Senior

Encl: Application

DEQ -TRO File 580 PPP

DΑΥ

Š Š

YEAR

DAY

<u>§</u>

YEAR

CERTIFICATE NO. TELEPHONE

JTHORIZED AGENT

DATE

PERMITTEE NAME/ADDRESS(INCLUDE FACILITY NAME/LOCATION IF DIFFERENT)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM(NPDES) COMMONWEALTH OF VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY

DISCHARGE MONITORING REPORT(DMR)

DISCHARGE NUMBER DA√ YEAR MO MONITORING PERIOD 001 բ DΑΥ PERMIT NUMBER VA0067423 § YEAR

FROM

FACILITY 7448 Wastewater Treatment Plant Rd, Tangier, VA LOCATION 23417

VA 23440

Tangier Town

NAME Tangler Tow ADDRESS PO Box 244

Tangier

VA 23462 5636 Southern Boulevard

DEPT. OF ENVIRONMENTAL QUALITY (REGIONAL OFFICE)

07/07/2009

Municipal Minor

Tidewater Regional Office

Virginia Beach

NOTE: READ PERMIT AND GENERAL INSTRUCTIONS
BEFORE COMPLETING THIS FORM.

									Ī	VOINT IOTOT	
PARAMETER		QUANTI	QUANTITY OR LOADING		J	QUALITY OR CONCENTRATION	CENTRATION		<u>8</u>	POPENCY POPENCY	SAMPLE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	STINO	<u></u>	ANALYSIS	ΙΥΡΕ
001 FLOW	REPORTD				*****	****	****				
	REGRMNT	0.10	NE	MGD	****	****	*****			COINT	REC
002 PH	REPORTD	****	*****			****					
	REGRMNT	*****	*****		6.0	*****	9.0	SU		1/DAY	GRAB
003 BOD5	REPORTD				*****						
	REGRMNT	11	17	KG/D	****	30	45	MG/L		1/W	4HC
004 TSS	REPORTD				****						
	REGRMNT	11	17	KG/D	*****	30	45	MG/L		1/W	4HC
005 CL2, TOTAL	REPORTD	****	****		****				-		
	REGRMNT	****	****		****	0.013	0.016	MG/L		1/DAY	GRAB
006 COLIFORM, FECAL	REPORTD	****	*****		*****		****				
	REGRMNT	****	*****		****	200	******	N/CML		1/W	GRAB
007 DO	REPORTD	****	******			****	****				
	REGRMNT	****	****		4.0	****	*****	MG/L		1/DAY	GRAB
068 TKN (N-KJEL)	REPORTD		****		***		*****				
	REGRMNT	NL	*****	KG/D	*****	NL	*****	MG/L		2 /M	4HC
ADDITIONAL PERMIT REQUIREMENTS OR COMMENTS	OMMENTS										

QLs: BOD5- 5 mg/l; TSS-1.0 mg/l; CL2-0.10 mg/l; TKN - 0.50 mg/l

		I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE	PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TYPED OR PRINTED NAME	NO ASSURE THAT QUALIFIED PERSONNEL PROPERLY CATHER AND EVALUATE THE INFORMATION	SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MAINGE THE SYSTEM OR PRINCIPAL EYEC ITIVE OFFICED OR ALTHORIZED ACT	THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION	SUBMITTED IS TO THE BEST OF MY KNOWLEDGE AND BELLEF TRUE, ACCURATE AND COMPLETE.	L AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION,	+	J.S.C. & 1001 AND 33 U.S.C. & 1319. (Penalties under these statutes may include	Eines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)	
CES		AW THAT THIS DOCUMENT AN	OR SUPERVISION IN ACCORD	SONNEL PROPERLY GATHER A	AY OF THE PERSON OR PERS	ISIBLE FOR GATHERING THE	IY KNOWLEDGE AND BELIEF	SNIFICANT PENALTIES FOR	FINE AND IMPRISONMENT F	1319, (Penalties under	eximum imprisonment of b	
OCCURRENCES	8)	IDER PENALTY OF LA	ER MY DIRECTION C	TAT QUALIFIED PERS	ASED ON MY INQUIR	IS DIRECTLY RESPON	TO THE BEST OF M	WAT THERE ARE SIG	R POSSIBILITY OF	1 AND 33 U.S.C. &	\$10,000 and/or ma	
AND	OVERFLOWS	I CERTIFY UN	PREPARED UND	NO ASSURE TH	SUBMITTED, B.	THOSE PERSON	SUBMITTED IS	E AM AWARE TO	INCLUDING TH.	J.S.C. & 100	Fines up to	

PERMITTEE NAME/ADDRESS (INCLUDE FACILITY NAME/LOCATION IF DIFFERENT)

Tangler Town

ADDRESS PO Box 244

VA 23440 Tangier

FACILITY 7448 Wastewater Treatment Plant Rd, Tangier, VA LOCATION 23417

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM(NPDES) COMMONWEALTH OF VIRGINIA
DEPARTMENT OF ENVIRONMENTAL QUALITY DISCHARGE MONITORING REPORT(DMR)

DISCHARGE NUMBER DA≺ δ MONITORING PERIOD 001 YEAR DAY PERMIT NUMBER VA0067423 9 YEAR

FROM

DEPT. OF ENVIRONMENTAL QUALITY (REGIONAL OFFICE)

07/07/2009

Municipal Minor

Tidewater Regional Office 5636 Southern Boulevard VA 23462 Virginia Beach

NOTE: READ PERMIT AND GENERAL INSTRUCTIONS BEFORE COMPLETING THIS FORM.

PARAMETER		QUANTI	QUANTITY OR LOADING		J	QUALITY OR CONCENTRATION	CENTRATION		Ŏ.	FREQUENCY OF	SAMPLE
		AVERAGE	MAXIMUM	UNITS	MINIMOM	AVERAGE	MAXIMUM	UNITS		ANALYSIS	
140 ENTEROCOCCI	REPORTD	****	****		****		****				
	REGRMNT	****	****		****	35	*****	N/CML		1/D-W	GRAB
157 CL2, TOTAL CONTACT	REPORTD	****	****			*****	****				
,	REQRMNT	****	****		1.5	*****	*****	MG/L	6	1/DAY	GRAB
213 CL2, INST TECH MIN	REPORTD	****	****			****	*****				
LIMIT	REGRMNT	****	****		09.0	****	*****	MG/L		1/DAY	GRAB
	REPORTD										
	REGRMNT									* * * * * * * *	
	REPORTD	,									
	REGRMNT									****	
	REPORTD										
	REGRMNT									****	
	пероятр										
	REQRIMINT									****	
	REPORTD		~								
	REGRIMIT									*****	
ADDITIONAL PERMIT REQUIREMENTS OR COMMENTS	OMMENTS										

QLs: BOD5- 5 mg/l; TSS-1.0 mg/l; CL2-0.10 mg/l; TKN - 0.50 mg/l

1	⊢		ᅳ	4		
Щ			MO.			MO.
DATE			YEAR			YEAR
			CERTIFICATE NO.	TELEPHONE		
OPERATOR IN RESPONSIBLE CHARGE			SIGNATURE	R OR AUTHORIZED AGENT		SIGNATURE
OPERATOR IN R			TYPED OR PRINTED NAME	PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TYPED OR PRINTED NAME
TOTAL BOD5(K.G.)		ATTACHMENTS WERE	PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION	SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM OR PHOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION	SUBMITTED IS TO THE BEST OF MY KNOWLEDGE AND BELIEF TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION,	INCLODING THE FOSSIBLIATY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS, SEE 18 7.5.C. & 1001 AND 33 U.S.C. & 1319, (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)
TOTAL FLOW(M.G.)		I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL, ATTACHMENTS WERE	PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INPORMATION	HE PERSON OR PERSONS WITCOM GATHERING THE INFOI	LEDGE AND BELIEF TRUE, IT PENALTIES FOR SUBMIT	INCLODING THE POSSIBLICTY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS, EER : 7.5.C. & 1001 AND 33 U.S.C. & 1319, (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years
TOTAL OCCURRENCES		PENALTY OF LAW THAT	MY DIRECTION OR SUPER QUALIFIED PERSONNEL P	D ON MY INQUIRY OF TH IRECTLY RESPONSIBLE F	THE BEST OF MY KNOWL THERE ARE SIGNIFICAN	OSSIBLLITY OF FINE AN ND 33 U.S.C. & 1319, ,000 and/or maximum i.
BYPASSES AND	OVERFLOWS	I CERTIFY UNDER	PREPARED UNDER 1 IO ASSURE THAT (SUBMITTED. BASE THOSE PERSONS DI	SUBMITTED IS TO I AM AWARE THAT	INCLUDING THE PA J.S.C. & 1001 AL Fines up to \$10,

DAY

DAY

Effluent Montoreng Reduction

dte dtrmnd	27-Feb-2004	22-Mar-2004	22-Apr-2004	25-May-2004	08-Jun-2004	23-Jul-2004	23-Sep-2004	22-Oct-2004	23-Nov-2004	22-Dec-2004	21-Jan-2005	21-Jan-2005	23-Feb-2005	25-Feb-2005	25-Feb-2005	25-Fab-2005	25-Feb-2005	25-Feb-2005	25-Feb-2005	25-Feb-2005	25-Feb-2005
Comments					·					dmr revd 12/20/04	CORRECTED DMRS RCVD 6/2/05	DO VALUE MISSING ON DMR FINALLY RCVD; DO VALUE RCVD 6/8/05	JAN DMR RCVD 37705; AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 3/7/05; AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 3/7/05; AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 3/7/05; AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 3/7/05, AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 3/7/05; AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 3/7/05; AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 37705; AMENDED DMR RCVD 6/2/05	JAN DMR RCVD 3/7/05; AMENDED DMR RCVD 6/2/05
WLNOV					W2004-05-T-					W2005-05-T- 1010	W2005-05-T- 1010	W2005-05-T-	W2005-05-T-								
Raw Pts SUM	2	.2	2.	2	7.0.r 7	2	ζi	vi	.2	V 7.	V .	7.0. V A	2.0 V	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Months Pts SUN R	.2	4.	90	8	2.8	2.0	1.8		1.8	<i>L</i> '	2.	1.7	2.7		2.7	2.7	. 2.7	2.7	2.2	2.7	2.7
al Points SUNS	si	c.	2.	2	1.0	2	Z.	2.	.2	τύ	.2	1.0	0,	O.	Ö.	oʻ	o.	o.	o.	lo.	o.
Raw Points SUMFinal Points SUN Months Pts SUN	.2	5.	.2	.2	0:		2,	7	2:	1.0	2	o; -	1.0	0.	0.	0.	O,	0.	0.	0.	O.
Reported													4	×	×	×	×	× .	×	×	×
Requirement														0.013	1000000	1000000	1000000	1000000	1000000	0.016	0.60
ilem	No signature/date/phone	No signature/date/phone, No telephone number	No signature/date/phone, no phone number	No signature/date/phone	complete reiss appl due 4/28/04partial submittal rcvd 4/26/04; add. info requested 5/5/04	No signature/date/phone, NO PHONE NUMBER	No signature/date/phone, no phone number	NO PHONE NUMBER; SIGNATURE DATE; MONITORING PERIOD SHOWN AS 9/1/04-8/30/04	No signature/date/phone	DMR due 12/10/2004 missing DMR.	improper - all units not documented on DMR	DMR due 01/10/2005 missing DMR.	Incomplete DMR (less than 25% data missing)		CONCAVG UNREPORTED PARAMETER	CONCAVG UNREPORTED PARAMETER	CONCAVG UNREPORTED PARAMETER	CONCAVG UNREPORTED PARAMETER	CONCAVG UNREPORTED PARAMETER		CONCMINUNREPORTED 0.60 PARAMETER
No Param Name														CLZ, TOTAL	PHOSPHORUS, TO CONCAVG— UNREPORTED PARAMETER	I I	TKN (N-K/EL)	NITRITE*NITRATE:	ORTHOPHOSPHAT	CIL2, TOTAL	CL2 INST TECH MI
Duffall NParam No														902	25.0	610	898	389	795	900	213
r Dutfall	001			100					8			004		004	5	001	1001	100	901	100	100
ih Year	2004	2004	2004	2004	2002	2004	2004	2004	2004	2004	2004	2004	2005	2005	2005	2005	2005	2005	2005	2005	2005
Month	3 JAN	FEB	MAR	3 APR	¥ ₩			SEP	DCT	2		DEC		NAU	N AN	NAC					NAU
Permit No	VA0067423	VA006742:	VA0067423	VA0067423	VA006742	VA0067423	VA0067423	VA0067423	VA0067423	VA006/42:	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423
Facility Name	Tangier Town	Tangier Town	Tangier Town	Tangier Town	langier Iown	Tangier Town	Tangier Town	Tangier Town	Tangier Town	sangler Lown	Tangier Town	angier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Fangler Town	Tangier Town

dte dtrmnd	25-Feb-2005	25-Feb-2005	25-Mar-2005	25-Mar-2005	27-Apr-2005	27-Apr-2005	27-Apr-2005	25-May-2005	25-May-2005	25-May-2005	23-Jun-2005	26-Jul-2005	26-Jul-2005	26-Aug-2005	26-Aug-2005	29-Sep-2005
Comments	JAN DMR RCVD 37705;SAMPLED FOR FC; CL2 NOT NEEDED				DO VALUE RCVD 8//8/05		177								RCVD 8/5/05	UNDER REVIEW BY TRO STAFF
WL/NOV		W2005-05-T- 1010	W2005-05-T- 1010	W2005-05-T- 1010		W2005-05-T-	W2005-05-T- 1010	W2005-05-T- 1010	W2005-07-T-	W2005-05-T- 1010	W2005-07-T-		W2005-07-T- 1011		W2005-07-T-	
Raw Pts SUM	2.0	2.0	2.0	2.0	3.0	3.0	3.0	5.0	5.0	5.0	2.0	. 2.2	2.2	3.0	3.0	1.0
Months Pts SUN	2.7	2.7	3.7	3.7	5.7	5.7	5.7	7.7	7.7	7.7	0.6	10.0	10.0	11.0	11.0	11.0
nai Points SUNB	0.	0,1	1.0	0.	o.	2.0	1.0	2.0	0.1	2.0	2.0	2.	2.0	1.0	2.0	1.0
Raw Points SUM-mai Points SUIB Months Pts SUIN Raw Pts SUIN	0	1,0	1.0	1,0	O.	2.0		2.0	0.1	2.0	2.0	.2	2.0	1.0	2.0	1.0
Reported	×				×			05/11/2005	05/11/2005						08/05/2005	
Requirement		01/26/2005	01/26/2005	02/10/2005.	4.0	01/26/2005	02/10/2005	01/26/2005	-04/10/2005	02/10/2005	02/10/2005		02/10/2005	07/10/2005	02/10/2005	07/1 0/2005
llem	CONOMIN-UNREPORTED PARAMETER	Compliance schedule: VERIFY EXISTING OR SUBMIT NEW O&M MANUAL	Compliance schedule: VERIFY EXISTING OR SUBMIT NEW O&M MANUAL	Compliance schedule: SCHEDULE OF COMPLIANGE - SUBMIT PLANS [for Achievement of Compliance]	CONCMINUNREPORTED	Compliance schedule: 01/26 VERIFY EXISTING OR SUBMIT NEW O&M	Compliance schedule: SCHEDULE OF COMPLIANCE - SUBMIT PLANS [for Achievement of Compliance]	Compliance schedule: VERIFY EXISTING OR SUBMIT NEW O&M MANUAL	Compliance schedule: ENF -04/10/2005 OTR 1 - SUBMIT QUARTERLY PROGRESS REPORT	Compliance schedule: SCHEDULE OF COMPLIANCE - SUBMIT PLANS (for Achievement of Compliance)	Compliance schedule: SCHEDULE OF COMPLIANCE - SUBMIT PLANS (for Achievement of Compliance)	no signature, no date, no telephone,	Compliance schedule: SCHEDULE OF COMPLIANCE - SUBMIT PLANS (for Achievement of Compliance)	Compliance schedule: ENF- QTR 2 - SUBMIT QUARTERLY PROGRESS REPORT	Compilance schedule: SCHEDULE OF COMPLIANCE - SUBMIT PLANS [for Achievement of Compliance]	Compliance schedule: 2ND 0 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE
Param Name	CLZ, TOTAL CONTA				00											
Outfall NParam No	157	F	1	E	1007		T.	-	1	ı	ı	-	F	1	-	1
Year Du				2005 001				2005 001			2005 001	2005 001		2005 001	2005 001	2005 001
Month	NAU	JAN	FEB	FEB		MAR	MAR	APR	APR	APR		NOr	NOC	nor	ant.	AUG
Permit No	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423
Facility Name	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	. Tangiər Town	Tangier Town	Tangier Town

dte dtrmnd	25-Oct-2005	28-Nov-2005	28-Nov-2005	28-Nov-2005	28-Nov-2005	28-Nov-2005	21-Dec-2005	21-Dec-2005	21-Dec-2005	21-Dec-2005	21-Dec-2005	25-Jan-2006	25√an-2006	25-Jan-2006	25-Jan-2006	25-Jan-2006	27-Feb-2006	27-Feb-2006	27-Feb-2006	27-Feb-2006
Comments	UNDER REVIEW BY TRO STAFF		UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW
WLNOV																				
Raw Pts SUM	2.0	5.0	9.0	5.0	5.0	5.0	5.2	5.2	5.2	5.2	5.2	8,2	88.2	8.2	8.2	8.2	0.6	0.6	0.6	9.0
onthis Pts SUN	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0	11.0
Points SUNS M	2.0	O,	2,0	1.0	1.0	0,1		2.0	0.1	1.0	0,1	2	2.0	2.0	2.0	2.0	2.0	2.0	1.0	2.0
Rew Points SUMFInal Points SUID Months Pts SUN Raw Pts SUM	2.0	o,	2:0	1.0	1.0	1.0	.2	2:0	1.0	1.0	1.0	2,	2.0	2.0	2.0	2.0	2.0	2.0	1.0	2.0
Reported		×																		
Requirement	07/10/2005	1000000	07/10/2005	10/10/2005	10/26/2005	10/26/2005		07/10/2005	10/10/2005	10/26/2005	10/26/2005		07/1/0/2005	10/10/2005	10/26/2005	10/26/2005	07/10/2005	10/10/2005	01/10/2006	0/26/2005
	schedule: 2ND RESS REPORT E OF SE	CONCAVG UNREPORTED PARAMETER		nedule: 3RD SS REPORT DF	Compliance schedule: Basis of Design	Compliance schedule: Interim Optimization Plan for Nutrient Removal	No signature/date/phone	Compliance schedule: 2ND (QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Basis 10/26/2005 of Design	Compliance schedule: Interim Optimization Plan for Nutrient Removal	no telephone number, new signatory name on DMR - checking delegation of authority		schedule; 3RD RESS REPORT E OF CE	44		Compilance schedule: 2ND COTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	hedule: 4TH SS REPORT DF	Compliance schedule: Basis 10/26/2005
Param Name	ALTERNATION CONTRACTOR	ОRTHOPHOSPHAT																		
Year Juttali N-aram No		795																		
аг Оштан		001	001	001		001		001			904	904	904	004		004	. 001	1001	5	100
Ē		r 2005	2005		2005	7 2005		7 2005	,							2005	2006	2006	2006	2008
						VA0067423 OCT		VA0067423 NOV								VA0067423 DEC	VA0067423 JAN	VA0067423 JAN	VA0067,423 JAN	VA0067423 JAN
			Tangier Town	Tangler Town						<u> </u>			Tangier Town						-	Tangier Town

dte dtrmnd	27-Feb-2006	27-Mar-2006	27-Mar-2006	27-Mar-2006	27-Mar-2006	27-Mar-2006	27-Apr-2006	27-Apr-2006	27-Apr-2008	27-Apr-2006	27-Apr-2006	27-Apr-2006	24-May-2006	24-May-2006	24-May-2006	24-May-2006	24-May-2006	24-May-2006	24-May-2006	26-Jun-2006	26-Jun-2006
Comments	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	1		UNDER REVIEW BY TRO STAFF
WLINOV																					
Raw Pts SUM	0.6	0.6	0.0	0.6	9.0	0.6	10.2	10.2	10.2	10.2	10.2	10.2	11.2	11.2	11.2	11.2	11.2	11.2	11.2	12.0	12.0
onths Pts SUN	11.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
I Points SUIB N	2.0	2:0	2.0	0.1	2.0	2:0	Ź	5.0	5.0	2.0	2,0	2.0	2	2.0	2.0	2.0	0.1	2.0	2.0	1:0	O.
Raw Points SUMFinal Points SUM Months Pts SUN Raw Pts SUM	2.0	2.0	2.0	1,0	2.0	2.0	Si	2.0	2:0	2.0	2.0	2.0	.2	2.0	2.0	2.0	1.0	2.0	2.0	1.0	0.
Reported		,								e e e e e e e e e e e e e e e e e e e											×
Requirement	10/26/2005	07/10/2005	10/10/2005	01/10/2006	10/26/2005	10/26/2005		07/10/2005	10/10/2005	01/10/2006	10/26/2005	10/26/2005		5002/01/20	10/10/2005	01/10/2006	04/10/2006	10/26/2005	10/26/2005		
ltem	Compliance schedule: Interim Optimization Plan for Nutrient Removal	Compilance schedule: 2ND QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Basis 10/26/2005 of Design	Compliance schedule: Interim Optimization Plan for Nutrient Removal	NO TELEPHONE NUMBER	Compliance schedule: 2ND QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Basis 10/26/2005 of Design	Compliance schedule: Interim Optimization Plan for Nutrient Removal	to signature/date/phone,	Compliance schedule: 2ND C QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE		Compilance schedule: 5TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Basis of Design	Compliance schedule: Interim Optimization Plan for Nutrient Removal	Incomplete DMR (less than 25% data missing)	CONCMINUNREPORTED 4.0 PARAMETER
Param Name)		1					0		1	00
Juffall N ^P aram No										ASIS M											400
Year Duff		2006 001		2006 001	2006 001	90 90						90		90		96 001)6 001		96 001		96 001
Worth Y									MAR 2006			MAR 2006		APR 2006		PR 2006	PR 2006				4Y 2006
Permit No 🐧				VA0067423 FE													VA0067423 APR		VA0067423 APR		VAGD67423 MAY
																					Tangier Town

dte dtmnd	28-Jun-2006	26-Jun-2006	26-Jun-2008	26-Jun-2006	26-Jun-2006	26-Jun-2006	25-Jul-2006	25-Jul-2006	25-Jul-2006	25-Jul-2006	25-Jul-2006	25-Jul-2006	25-Aug-2006	25-Aug-2006	25-Aug-2006	25-Aug-2006	25-Aug-2006	25-Aug-2006	25-Aug-2006
Comments	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW	UNDER REVIEW BY TRO STAFF
WCNOV																			
caw Pts SUM	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	11.5	11.5	11.5	11.5		11.5	11.5
lonns Pris SUN P	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
N Q Q SUISL III	2.0	2.0	2.0	0,1	2.0	2.0	2.0	5.0	2.0	2.0	2.0	2.0	ιτί	2.0	2.0	2.0	1.0	2.0	2.0
NOW STATES OF THE FORMS OF THE PROPERTY AND THE VOICE STATES OF TH	2.0	2.0	2.0	0.1	2.0	2.0	2.0	2.0	5.0	2.0	2.0	2.0	тó	2.0	2.0	2.0	1.0	2.0	2.0
Sounday.	,												2				-	08/08/2006	08/08/2006
Kequiramen	07/10/2005	10/10/2005	01/10/2006	04/10/2006	10/26/2005	10/26/2005	07/10/2005	10/10/2005	01/10/2006	04/10/2006	10/26/2005	10/26/2005	6.0	10/10/2005	01/10/2006	04/10/2006	07/10/2006	0/26/2005	10/26/2005
		Compliance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 5TH TO OTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Basis 10/26/2005 of Design	Compliance schedule: Interim Optimization Plan for Nutrient Removal			Compilance schedule: 4TH In QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 5TH 9 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Basis 10/26/2005 of Design	Compliance schedule: Interim Optimization Plan for Nutrient Removal		Compliance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	redule: 5TH SS REPORT DF	Compliance schedule: 6TH OTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Basis 10/26/2005 of Design	Compilance schedule: Interim Optimization Plan for Nutrient Removal
1													Hd						
													200						
		00 001	06 001	06 001					90		96 001	DG 001)6 001		90	96		90 PO
			۱۲ 2006 ۱۲	١٧ 2006					2006 2006			N · 2006					-		5006
960/06			VA0067423 MAY						VA0067423 JUN			VA0067423 JUN	Т		VA0067423 JUI	VA0067423 JUL			VA0067423 JUL
		Tangier Town							Tangier Town VA						ii	•			Tangier Town VA

dte dtrmnd	25-Sep-2006	25-Sep-2006	25-Sap-2006	25-Sep-2006	27-Oct-2006	27-Oct-2008	27-Oct-2006	27-Oct-2008	27-Nov-2006	27-Nov-2008	27-Nov-2006	27-Nov-2006	27-Dec-2006	27-Dec-2006	27-Dec-2006	27-Dec-2006	27-Dec-2006
Comments	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF		UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF			
Pts SUM WLNOV	7.0	0.7	7.0	7.0	0.8	0.8	8.0	8.0	0.7	7.0	0.7	7.0	7.0	7.0	7:0	2.0	7.0
Raw Points SUMFinal Points SUIS Months Pts SUN Raw Pts SUM	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
nal Points SUNS Mc	2.0	2.0	2.0	0.5	2.0	5.0	2.0	2.0	2.0	2.0	2.0	1.0	o.	2.0	5.0	2.0	1.0
Raw Points SUMF	2.0	2.0	2.0	1.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.0	o.	2.0	2.0	2.0	1.0
Reported													×_				
A	10/10/2005 {T	ττ ετ	1 04/10/2006 1T		10/10/2005 8T	t 01/10/2006		t .07/10/2006 tT	1 01/10/2006	1T 04/10/2006	1 07/10/2006 1T	10/10/2006 tT	D 4.0	1 01/10/2006	1. 04/10/2006	1 07/11 0/2006	10/10/2006
ltem	Compliance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 5TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 3RD QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 5TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schodule: 5TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule; 7TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	CONCMIN-UNREPORTED 4.0 PARAMETER	Compliance schedule: 4TH 0 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 5TH QTR. PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 7TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE
Param Name													DO				
Dulfali NParam No	1	1	1	н	И	H	И	H	L	1	1	1	1 007		-	-	-
					2006 001	2006 001		2006 001	2006 001	2006 001		2006 001		2006 001	2006 001	2006 001	2006 001
Month	AUG	AUG	AUG	AUG	SEP	SEP	SEP	SEP	ост	ост	ост	ост	NOV	<u> </u>	NON.	AON.	NON.
Permit No	VA0067423	VA0067423	VA0067423	VA0067423		VA0067423											
Facility Name	Tangier Town	Tangler Town	Tangier Town	Tangler Town	Tangier Town	Tangler Town	⊺angier Town	Tangier Town	Tangier Town	Tangier Town	Tangler Town	Tangier Town					

dte dtrmnd	2007	2007	2007	2002	2007	2007	2007	2007	2007	2007	2007	2007	2007	2003	2003	200 2	200
dte d	25-Jan-2007	25-Jan-2007	25-Jan-2007	25-Jan-2007	25-Jan-2007	28-Feb-2007	26-Feb-2007	26-Feb-2007	26-Feb-2007	27-Mar-2007	27-Mar-2007	27-Mar-2007	27-Mar-2007	26-Apr-2007	26-Apr-2007	26-Apr-2007	26-Apr-2007
Comments	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF
WLNOV							,						7 7 7 7 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8				
Raw Pts SUM	8.2	8.2	8.2	8.2	8.2	7.0	7.0	7.0	7.0	7.0	7.0	0.7	7.0	0.8	9:0	8.0	8.0
onths Pts SUN	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12:0	12.0
al Points SUNS M	.2	2.0	5.0	2.0	2.0	2.0	2.0	2.0	1,0	2.0	2.0	2.0	0.	2.0	2.0	2.0	2.0
Raw Points SUMFinal Points SUMS Months Pts SUN Raw Pts SUM	.2	2.0	2.0	2:0	2:0	2:0	2.0	2.0	1.0	2.0	2.0	2.0	1.0	2.0	2.0	5.0	2.0
Reported															-		
Requirement		01/10/2006	04/10/2006	07/10/2006	10/10/2006	04/10/2006	07/10/2006	10/10/2006	01/10/2007	04/10/2006		10/10/2006	01/10/2007	04/10/2006	07/1/0/2006	10/10/2006	01/10/2007
them the second	No phone number - DMR is missing requirements and two are insccurate	Compliance schedule: 4TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 5TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 7TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 5TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH 0 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	nedule: 7TH SS REPORT JF	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 5TH 04/10/2006 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 7TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH 01/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 5TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 7TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH 01/10/2007 OTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE
Param Name																	
Param No																	
Dutfall Nearem No	001	001	001	100	100	001		9 64	001	001	001	001			001	001	001
Year	2006	2006	2006	2006	2006	2007					2007		2007	2007	2007		2007
Month	DEC	DEC	DEC	DEC	DEC	JAN	JAN	JAN	JAN	FEB	FEB	FEB	FEB	MAR	MAR	MAR	MAR
Permit No	VA0067423			VA0067423	VA0067423					VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423		VA0067423
Facility Name	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangler Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town

dte dirmnd	24-May-2007	24-May-2007	24-May-2007	24-May-2007	25-Jun-2007	25-Jun-2007	25-Jun-2007	25-Jun-2007	25-Jul-2007	25-Jul-2007	25-Jul-2007	25-Jul-2007	27-Aug-2007	27-Aug-2007	27-Aug-2007	27-Aug-2007	27-Aug-2007	27-Aug-2007
Comments	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF
W WLNOV	7.0	7.0	7.0	7.0	7.0	7.0	7.0	0.7	8.0	0.8	0.8	8.0	8.0	8.0	0.8	0.8	0.0	8:0
REW PIS SI																		
onins Pris Sur	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
Nail Points Sund M	2,0	2.0	5.0	0:	5.0	2.0	2.0	0,1	2.0	25.0	2.0	2.0	1.0	oʻ	1.0	2.0	2.0	2:0
New Politis SUM-First Politis SUID MOTHS FIR SUN NEW FIR SUM	2.0	2.0	2.0	1,0	2.0	2:0	2:0	1.0	2.0	2.0	2.0	2.0	1.0	O.	1.0	2.0	5.0	2.0
repored														×				
	07/10/2006	10/10/2006	01/10/2007	04/10/2007	07/10/2006	10/10/2006	01/10/2007	04/10/2007	07/10/2006	10/10/2006	01/10/2007	04/10/2007	. :	4.0	07/10/2007	10/10/2006	01/10/2007	04/10/2007
Helli	Compilance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 71H 1 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH 01/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH 0 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 7TH 1 QTR PROGRESS REPORT - SCHEDULE OF COMPLANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 6TH 10 QTR PROGRESS REPORT SCHEDULE OF COMPLIANCE	Compliance schedule: 7TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	adula: 8TH		Incomplete DMR (less than 25% data missing)	CONCMIN-UNREPORTED PARAMETER	Compliance schedule: 10TH 07/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 7TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH 0 QTR PROGRESS REPORT SCHEDULE OF COMPLIANCE	Compilance schedule: 8TH 0 QTR PROGRESS REPORT - SCHEDULE OF COMPLANCE
Pin N														ĐO C				
N														700				
	2007 001		2007 001	2007 001			2007 001		2007 001	2007 001	2007 001				2007 001	2007 001	2007 001	2007 001
i i	APR 20		APR 20	APR 20			MAY 20		JUN 20	30N 30	3CN 3CN				JUL 20	JUL 20		JUL 20
S217 (C0-597/A				VA0067423 /			VA0067423 P				VA0067423							VA0067423
0 mg 6 mg 6	「angier ⊺own	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Fangier Town	Fangier Town	Tangier Town	angier ⊺own	angler Town	fangier Town	Fangier Town	Fangier Town	Tangier Town	Tangier Town	fangier Town	Tangier Town	Fangier Town

dte dtmnd	25-Sep-2007	25-Sep-2007	25-Sep-2007	25-Sep-2007	25-Sep-2007	25-Sep-2007	24-Oct-2007	24-Oct-2007	24-Oct-2007	24-Oct-2007	24-Oct-2007	27-Nov-2007	27-Nov-2007	27-Nov-2007	27-Nov-2007	27-Nov-2007	20-Dec-2007
Comments		-	UNDER REVIEW 2 BY TRO STAFF	UNDER REVIEW 2 BY TRO STAFF	UNDER REVIEW 2 BY TRO STAFF	UNDER REVIEW 2 BY TRO STAFF	Rpt/Lim: Mth2: .129419/0.10 Mth1; .119217/0.10	UNDER REVIEW 2 BY TRO STAFF	UNDER REVIEW 2 BY TRO STAFF	UNDER REVIEW 2 BY TRO STAFF	UNDER REVIEW 2 BY TRO STAFF	95% flow ltr sent; 2 Rpt/Lim: Mth2: .112/0.10 Mth1:	EW RO	UNDER REVIEW 2 BY TRO STAFF	UNDER REVIEW 2 BY TRO STAFF	_	Rpt/Lim: Mth2: 20 .124/0.10 Mth1: .112/0.10
MLMOV												0			-		
Raw Pts SUN	8.2	8.2	8.2	8,2	8.2	8.2	8.0	8.0	8.0	8.0	8.0	7.0	7.0	7.0	7.0	7.0	0.7
Months Pts SUI	12.0	12.0	12.0	12.0	12.0	12,0	12.0	12.0	12.0	12.0	12.0	12.0	. 12.0	12.0	12.0	12.0	12.0
nal Points SUM I	.2	1,0	1.0	2.0	2.0	2:0		2.0	2.0	2.0	2:0		2.0	0.	2.0	2.0	
Raw Points SUM-inal Points SUIS Months Pis SUN Raw Pts SUM	2.	1.0	1.0	2.0	2.0	2:0		2.0	2.0	2.0	2.0		2.0	0.	2.0	2.0	
Reported	,	401	.				11.					.124		-			113
Requirement		200	07/10/2007	10/10/2006	01/10/2007	04/10/2007	0.10	07/10/2007	10/10/2006	01/10/2007	04/10/2007	0.10	07/1/0/2007	10/10/2007	01/10/2007	04/10/2007	0.10
a service of the serv	using outdated DMR form - includes nutrients which are now on the GP VAN# DMR.	CONCAVG	Compliance schedule: 10TH 07/10/2000 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 7TH QTR PROGRESS REPORT SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH CORP PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Reported value is >= 95% of the design capacity for the 3rd consecutive month	Compliance schedule: 10TH 07/10/2003 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule, 7TH QTR PROGRESS REPORT SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Reported value is >= 95% of the design capacity for the 3rd consecutive month	Compliance schedule: 10TH 07/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 111H 10/10/2007 OTR.PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Reported value is >= 95% of the design capacity for the 3rd consecutive month
Param Name		COLIFORM, FECAL C					FLOW					FLOW 6					FLOW
Dutfell Nearem No		900					100					001					100
Year Duffe	2007 001	_	2007 001		2007 001	2007 001	2007 00 1		2007 001					2007 001	2007 001	2007 001	2007 001
Month			AUG 20		AUG 20	AUG 20								OCT 20	ост 20		NOV 20
Permit No						VA0067423 /								VA0067423 C			VA0067423 N
Facility Name	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangler Town	Tangier Town	Tangier Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town

dte dtmnd	20-Dec-2007	20-Dec-2007	20-Dec-2007	20-Dec-2007	24-Jan-2008	24-Jan-2008	24-Jan-2008	24-Jan-2008	24-Jan-2008	25-Feb-2008	25-Feb-2008	25-Feb-2008	25-Feb-2008	25-Feb-2008	26-Mar-2008	26-Mar-2008	26-Mar-2008
Comments	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	RpVLim; Mth2: .113/0.10 Mth1: .124/0.10	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	UNDER REVIEW BY TRO STAFF	Rpt/Lim: Mth2: 0.109/0.10 Mth1: .113/0.10	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	UNDER STAFF REVIEW	UNDER STAFF REVIEW	UNDER STAFF REVIEW
ts SUM WL/NOV	7.0	2.0	7.0	7,0	0.8	8.0	0.8	0.8	8.0	2.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
Raw Points SUM-inal Points SUIB Montits Fits SUIN Raw Pts SUM	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
AFinal Points SUNS M	2.0	1.0	20.0	5.0		2.0	2.0	2.0	2.0		5.0	2.0	1.0	2.0	2.0	2.0	1.0
	2.0	1:0	2.0	2.0		2:0	2.0	2.0	2.0		2.0	2.0	1.0	2.0	2.0	2.0	1.0
ment Reported					0.109					.102							
Requirement	: 10TH 07/10/200	: 11TH 10/10/200	shedule: 8TH 01/10/2000	8TH 04/10/2007	95% 0.10 for nonth	: 10TH 07/10/200	: 11TH 10/10/200	87H 01/10/200	8TH 04/10/2007	95% 0.10 for lonth	10TH 07/10/2007	PORT PO/10/2007	12TH 01/10/2006	8TH 04/10/2007	10TH 07/10/2007 PORT	hedule: 11TH 10/10/2007 SS REPORT OF	12TH 01/10/2008 PORT
Item	Compliance schedule: 10TH 0 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 11TH 10/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule QTR PROGRESS RE - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Reported value is >= 95% of the design capacity for the 3rd consecutive month	Compliance schedule: 10TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 11TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Reported value is >= 95% of the design capacity for the 3rd consecutive month	Compliance schedule: 10TH 07/10/2007 OTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 11TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 12TH 01/10/2008 OTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 10TH 07/10/2000 OTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule QTR PROGRESS RE - SCHEDULE OF COMPLIANCE	Compilance schedule: 12TH 01/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE
Param Name					FLOW					FLOW							
Outfell N ² aram No	001	001		001	001 001	001	001	21	1	001 (00)	001	001	K	Б	<u> </u>	Σ .	E
- 1						2007 00			2007 001	2008 00	!	2008 00	2008 001	2008 001	2008 001	2008 001	2008 001
					DEC	DEC			DEC	JAN	NAU	JAN	JAN	JAN		FE8	FEB
Permit No	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423
Facility Name	Tangier Town	Tangler Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangler Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town

dte atmnd	26-Mar-2008	24-Apr-2008	24-Apr-2008	24-Apr-2008	24-Apr-2008	22-May-2008	22-May-2008	22-May-2008	22-May-2008	24-Jun-2008	24-Jun-2008	24-Jun-2008	24-Jun-2008	24-Jul-2008	24-Jul-2008	24-Jul-2008	24-Jul-2008
Comments	UNDER STAFF REVIEW		CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW
WLNOV															* 55		
Raw Pts SUM	7.0	8.0	8.0	8.0	8.0	7.0	7.0	2.0	7,0	7.0	0'.2	7.0	7.0	8.0	8.0	8.0	8.0
onthis Pits SUN	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
Points SUNS M	2.0	2.0	2.0	2.0	2.00	2.0	2.0	2.0	1.0	2.0	2.0	2.0	0.1	2.0	2.0	2.0	2.0
Raw Points SUMFinal Points SUM Months Pits SUM Raw Pits SUM	2.0	2:0	2:0	2.0	2.0	2:0	2.0	2.0	1.0	2.0	2.0	2.0	1.0	2.0	2.0	2.0	2.0
Reported											·						
Requirement	04/10/2007	07/10/2007	10/10/2007		04/10/2007	· 7002/01/70	10/10/2007	01/10/2008	04/10/2008	07/10/2007	10/10/2007	01/10/2008	04/10/2008	07/10/2007	10/10/2007	01/10/2008	04/10/2008
A the state of the	Compilance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 10TH CQTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 11TH 10/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	shedule: 12TH ESS REPORT OF	Compilance schedule: 8TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 10TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 11TH 10/10/2007 QTR PROGRESS REPORT - SCHEDULE OF. COMPLIANGE	Compliance schedule: 12TH 01/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 107H 07/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 11TH 10/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 12TH 0 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 13TH of QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 10TH 07/10/2007 OTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schevule: 11TH 19/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 12TH 01/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE
Param Name																	
Duffall NParam No				CAS PRO						-			16630				
Year Duff			2008 001		2008 001		2008 001	2008 001	2008 001	2008 001	2008 001	2008 001	2008 001	2008 001	2008 001	·	2006 001
Month			MAR 2			APR 2	APR 2		APR 2			MAY	MAY 2	NUU	N N N		NUL
Permit No	VA0067423	VA0067423	VA0067423				VA0067423						VA0067423	VA0067423			VA0067423
Facility Name	Tangier Fown	Tangler Fown	Tangier Town	Tangier Town	Tangier Town	Tangler Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town

dte dtmnd	22-Aug-2008	22-Aug-2008	22-Aug-2008	22-Aug-2008	24-Sap-2008	24-Sep-2008	24-Sep-2008	27-Oct-2008	27-Oct-2008	27-Oct-2008	27-Oct-2008	21-Nov-2008	21-Nov-2008	21-Nov-2008	22-Dec-2008	22-Dec-2008	22-Dec-2008
Comments	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW
WUNOV																	
MUS SIL W	2.0	7.0	0.7	0.7	6.0	0.0	6.0	6.2	6.2	6.2	6.2	4.2	2.4	7.	9:0	0,00	6.0
	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
	2.0	2.0	2.0	1.0	2.0	2.0	5.0	7.	2:0	5.0	2.0	ci	2.0	2.0	2.0	2.0	1.0
MOO 2011 XXX 200 011 812 101 2010 101 101 101 101 101 101 101	2.0	\$ 2.0	2.0	0.1	2.0	2.0	2.0	2	2.0	2.0	5.0	2 i	2.0	2.0	2.0	2.0	1.0
				08/12/2008								56					
	10/10/2007	01/10/2008	04/10/2008	07/10/2008	10/10/2007	01/10/2008	04/10/2008		10/10/2007	01/10/2008	04/10/2008		01/10/2008	04/10/2008	01/10/2008	04/10/2008	11/01/2008
	Compliance schedule: 11TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 12TH/01/02008 QTR PROGRESS REPORTSCHEDULE OF COMPLIANCE	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 14TH 07/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 117H 10/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 12TH 01/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE		Compliance schedule: 11TH 10/10/2007 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 12TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	CONCMAX	Compliance schedule: 12TH 01/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compilance schedule: 12TH QTR PROGRESS REPORT - SCHEDILLE OF COMPLIANCE	Compliance schedule: 13TH/04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Achieve Compliance - final limits for enterococci
												BODS					O 4 iii
												500					
	2008 001					2008 001				2008 001				2008			2008 001
		JUL 28								SEP 20			·				NOV NOV
9811118333										VA0067423							VA0067423 N
	angter Town	Tangier Town	Tangier Town	Tangier Town	fangler Town	Tangier Town	langier Town	rangier Town	angler I own	rangier Town	angier Town	angier Fown	langier Town	angier Town	rangier Town	angier Town	Tangier Town

			1	1	1	ı	1		· · · · ·	γ		1	1	- ·
dte dtrmnd	26~Jan-2009	26-Jan-2009	26-Jan-2009	03-Feb-2009	24-Feb-2009	24-Feb-2009	23-Mar-2009	23-Mar-2009	23-Apr-2009	23-Apr-2009	27-May-2009	27-May-2009	23-Jun-2009	23-Jun-2009
Comments	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	corrected DMR rovd 1/12/09	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW	CURRENTLY UNDER STAFF REVIEW				
WLNOV	0.01	0 1 2	031	0.2	0 3 2	0 - 1	0 3 11	0312	032	0.21	W2009-06-T- 1008			
Raw Pts SUM	B.O	9:0	6.0	0.6	4.0	4.0	4.0	4.0	4.0	4.0	0.6	3.0	300	O.S.
forths Pts SUN	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0	12.0
al Pointe SUNS A	2.0	2,0	1,0	0.7	2.0	2.0	2.0	2.0	2.0	2.0		2.0	0.	2.0
Raw Points SUMFinal Points SUMS Months Pits SUM Raw Pts SUM	2.0	2.0	0.1	1.0	2.0	2.0	2.0	2.0	2.0	2:0	101	2.0	0.1	2.0
Reported		-		1/12/09										
Requirement	01/10/2008	04/10/2008	11/01/2008	12/10/08	04/10/2008	11/01/2008	04/10/2008	11/01/2008	04/10/2008	11/01/2008	04/25/2009	11/01/2008	04/25/2009	11/01/2008
ltem	Compliance schedule: 12TH QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE		Using older DMR - does not show pram #140 which has start date of 11/1/08 w/ 1st DMR due 12/10/08	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Achieve Compliance - final limits for enterococci	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Achieve Compliance - final limits for enterococci	Compliance schedule: 13TH 04/10/2008 QTR PROGRESS REPORT - SCHEDULE OF COMPLIANCE	Compliance schedule: Achieve Compliance - final limits for enterococci	Compliance schedule: SUBMIT VPDES PERMIT APPLICATION BEFORE 180 DAYS PRIOR TO PERMIT EXPIRATION	Compliance schedule: Achieve Compliance - final limits for enterococci	Compliance schedule: SUBMIT VPDES PERMIT APPLICATION BEFORE 180 DAYS PRIOR TO PERMIT EXPIRATION	Compilance schedule: Achieve Compilance - final limits for enterococci
Param Name				ENTEROCOCCI										
Ouffall NParam No			Special	140										
				001		994		001		000	1001	200	001	004
	2008	2008		2008	5000	2009	2009	2009		2009	2009	2009	2009	2009
00000000000000000000000000000000000000				3 DEC				3 FEB			3 APR	3 APR	3 MAY	3 MAY
Permit No	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423	VA0067423
Facility Name	Tangier Town	Tangier Town	Tangier Town	Tangiər Town	Tangier Fown	Tangier Town	Tangier Town	Tangler Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town	Tangier Town